

Control Inputs within venue (AV/3 Containment)


Worklight and Blue switching/dimming

Notes:-


KEY:

Refer to Facilities Schedule for cable type definitions

	D5U - DMX data wiring
	D6U - Ethernet data wiring
	230V Power cabling
	Low-voltage cabling for LEDs
	Z05 - Master control panel wiring
	Z09 - Push button panel wiring -it may be possible to daisy-chain the wiring around these panels - to be confirmed by the Specialist Contractor



Local dimmer switch in wiring circuit



Local 1-way switch in wiring circuit

SLB/WLC/WLM back boxes are to be specified, supplied and installed by the Specialist Contractor, as part of the containment system.

Scale	Size	Status	
NTS	A1	Tender	
Drawn	Date	Checked	Date
SDE	10/10/25	JN	05/11/2025
DRAWING NUMBER		REV	
LVC-CBL-WL-SC-001		A	

