

7 Ashtree Court - Woodsy Close - Cardiff Gate Business Park - Cardiff - CF23 8RW
Tel: 029 2054 7000 - Fax: 029 2054 7001 - www.shear-design.com - enquiries@shear-design.com

Contract No:	24100.D041
Date:	DECEMBER 2024
By:	JD


24100 – D041

47 BRO DARWEL

MERTHYR VALLEYS HOMES

STRUCTURAL CALCULATIONS PACKAGE

REF	INPUT	OUTPUT
	<p> $\theta = 18^\circ$ $h = 2.45$ $\phi = 30$ $lc = 0.72$ </p>	
	$F_{soil} = 0.72 \times 2.45^2 \times 18 \times 0.5 = 39 \text{ kN}$ $F_q = 0.72 \times 2.56 \text{ m}^2 \times 2.45 \text{ m} = 4.5 \text{ kN}$ <p>Moment</p> $(39 \times 2.45 \times 0.23) + (4.5 \times 2.45 \times 0.5)$ $= 37.1 \text{ kNm}$ $MIS = 37.1 \times 1.45 = 54 \text{ kNm}$ <p>STEM - try 225mm</p> $d = 225 - 40 - 10 - 8 = 167 \text{ mm}$ $K = 54 \times 10^6 / (82 \times 167^2 \times 1000) = 0.06$ $z/d = 0.94$ $AS = 54 \times 10^6 / (0.87 \times 800 \times 0.94 \times 167)$	790mm ²
	8785 mm² + vertical starters =	OK
	H10 @ 100 FF1 H12 STARTER BARS @ 100 NF1 + FF1 H10 @ 200 NF1	

REF	INPUT	OUTPUT
SLIDING	$F_2 = 43.5 \text{ kN}$ $F_v = 91.7 \text{ kN}$	
Ø BASE '35'	$\tan \phi = \tan 35^\circ = 0.7$ $0.7 \times 91.7 = 65 \text{ kN}$ $65 / 43.5 = 1.5 \therefore \underline{OK}$	
	<p><u>CONCRETE</u></p> <p><u>STEM OK</u></p> <p>BASE MAX = 100 kN/m^2</p> 	
	$M = (87 \times 1.74 \times 0.5) \times 1.74 / 3 = 45 \text{ kNm}$ $(U15) = 45 \times 1.5 = 68 \text{ kNm}$ $68 \times 10^6 / (32 \times 1000 \times 240^2) = 0.036$ $z/d = 0.95$ $AS = 68 \times 10^6 / (0.87 \times 500 \times 0.95 \times 240)$ $= 685 \text{ mm}^2 \therefore \underline{875 \text{ mm}^2} \quad \underline{OK}$	
	H12 @ 150 T1&T2 + B1&B2	

REF	INPUT	OUTPUT
	Take moments about centre = 0.9m	
	Base = $0.3 \times 25 \times 1.8m = 13.5kN @ 0 = 0kNm$	
	Stem = $0.225 \times 25 \times 2.15 = 12.1kN @ 0.825 = 7.8$	
	Soil 1 = $1.425 \times 2.15 \times 18 = 56kN @ -0.2m = -11.2$	
	Soil 2 = $1.425 \times 0.8 \times 0.5 \times 18 = 6.5kN @ -0.25m = -1.7kNm$	
	Q = $1.425 \times 2.5 = 3.6kN @ 0.2 = -0.72kNm$	
	TOTAL	91.7kN
		-6.12kNm
<u>BERMING</u>	$F/A + M/Z$	
	$91.7/1.8 + ((321 - 6.12) \times 6 / 1.8^2) = 108kN/m^2$	
	∴ INCREASE TO 2m WIDTH	OF 100k/m ²
	$31/91.7 = e = 0.33m$	
	$2m/6 = 0.33$ ∴ MIDDLE THIRD OF	
<u>OVERSTRESS</u>	$M = 37.1kNm$	
	RESTORING. TAKE MOMENTS @ TOE	
	Base = $13.5 \times 1m = 13.5$	
	Stem = $12.1 \times 0.23m = 3kNm$	
	Soil 1 = $56 \times 1.2m = 67kNm$	
		83kNm
	$83/37.1 = 2.2 > 1.5$ OF	

Project				Job no.	
Calcs for				Start page no./Revision 1	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

RETAINING WALL ANALYSIS

In accordance with EN1997-1:2004 incorporating Corrigendum dated February 2009 and the UK National Annex incorporating Corrigendum No.1

Tedds calculation version 2.9.22

Analysis summary

Design summary

Overall design utilisation 0.804
Overall design status Pass

Description	Unit	Capacity	Applied	F o S	Result
Sliding stability	kN/m	54.4	41.7	1.306	PASS
Overturning stability	kNm/m	119.8	43.7	2.745	PASS
Bearing pressure	kN/m ²	109.6	81.2	1.349	PASS

Design summary

Description	Unit	Provided	Required	Utilisation	Result
Shear resistance	kN/m	114.8	19.5	0.170	PASS
Base top face - Flexural reinforcement	mm ² /m	565.5	367.5	0.650	PASS
Base bottom face - Flexural reinforcement	mm ² /m	565.5	329.8	0.583	PASS
Base - Shear resistance	kN/m	114.8	19.5	0.170	PASS
Min. transverse stem reinf.	mm ² /m	392.7	225.0	0.573	PASS
Min. transverse base reinf.	mm ² /m	392.7	113.1	0.288	PASS

Retaining wall details

Stem type Cantilever
Stem height $h_{\text{stem}} = 2175$ mm
Stem thickness $t_{\text{stem}} = 225$ mm
Angle to rear face of stem $\alpha = 90$ deg
Stem density $\gamma_{\text{stem}} = 25$ kN/m³
Toe length $l_{\text{toe}} = 150$ mm
Heel length $l_{\text{heel}} = 1625$ mm
Base thickness $t_{\text{base}} = 300$ mm
Base density $\gamma_{\text{base}} = 25$ kN/m³
Height of retained soil $h_{\text{ret}} = 2175$ mm
Angle of soil surface $\beta = 18$ deg
Depth of cover $d_{\text{cover}} = 0$ mm

Retained soil properties

Soil type Medium dense well graded sand
Moist density $\gamma_{\text{mr}} = 21$ kN/m³
Saturated density $\gamma_{\text{sr}} = 23$ kN/m³
Characteristic effective shear resistance angle $\phi'_{r,k} = 35$ deg
Characteristic wall friction angle $\delta_{r,k} = 17.5$ deg

Base soil properties

Soil type Medium dense well graded sand
Soil density $\gamma_b = 18$ kN/m³
Characteristic cohesion $c'_{b,k} = 0$ kN/m²
Characteristic effective shear resistance angle $\phi'_{b,k} = 35$ deg
Characteristic wall friction angle $\delta_{b,k} = 15$ deg
Characteristic base friction angle $\delta_{bb,k} = 30$ deg

Project				Job no.	
Calcs for				Start page no./Revision 3	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Variable unfavourable action $\gamma_Q = 1.500$
Variable favourable action $\gamma_{Qf} = 0.000$

Partial factors for soil parameters – Table A.4 - Combination 1

Soil parameter set M1
Angle of shearing resistance $\gamma_{\phi'} = 1.00$
Effective cohesion $\gamma_{c'} = 1.00$
Weight density $\gamma_{\gamma} = 1.00$

Retained soil properties

Design moist density $\gamma_{mr'} = \gamma_{mr} / \gamma_{\gamma} = 21 \text{ kN/m}^3$
Design saturated density $\gamma_{sr'} = \gamma_{sr} / \gamma_{\gamma} = 23 \text{ kN/m}^3$
Design effective shear resistance angle $\phi'_{r,d} = \text{atan}(\tan(\phi'_{r,k}) / \gamma_{\phi'}) = 35 \text{ deg}$
Design wall friction angle $\delta_{r,d} = \text{atan}(\tan(\delta_{r,k}) / \gamma_{\phi'}) = 17.5 \text{ deg}$

Base soil properties

Design soil density $\gamma_{b'} = \gamma_b / \gamma_{\gamma} = 18 \text{ kN/m}^3$
Design effective shear resistance angle $\phi'_{b,d} = \text{atan}(\tan(\phi'_{b,k}) / \gamma_{\phi'}) = 35 \text{ deg}$
Design wall friction angle $\delta_{b,d} = \text{atan}(\tan(\delta_{b,k}) / \gamma_{\phi'}) = 15 \text{ deg}$
Design base friction angle $\delta_{bb,d} = \text{atan}(\tan(\delta_{bb,k}) / \gamma_{\phi'}) = 30 \text{ deg}$
Design effective cohesion $c'_{b,d} = c'_{b,k} / \gamma_{c'} = 0 \text{ kN/m}^2$

Using Coulomb theory

Active pressure coefficient $K_A = \sin(\alpha + \phi'_{r,d})^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta_{r,d}) \times [1 + \sqrt{[\sin(\phi'_{r,d} + \delta_{r,d}) \times \sin(\phi'_{r,d} - \beta) / (\sin(\alpha - \delta_{r,d}) \times \sin(\alpha + \beta))]}])^2 = 0.310$
Passive pressure coefficient $K_P = \sin(90 - \phi'_{b,d})^2 / (\sin(90 + \delta_{b,d}) \times [1 - \sqrt{[\sin(\phi'_{b,d} + \delta_{b,d}) \times \sin(\phi'_{b,d}) / (\sin(90 + \delta_{b,d}))]}])^2 = 6.555$

Sliding check

Vertical forces on wall

Wall stem $F_{stem} = \gamma_{Gf} \times A_{stem} \times \gamma_{stem} = 12.2 \text{ kN/m}$
Wall base $F_{base} = \gamma_{Gf} \times A_{base} \times \gamma_{base} = 15 \text{ kN/m}$
Moist retained soil $F_{moist_v} = \gamma_{Gf} \times A_{moist} \times \gamma_{mr'} = 83.2 \text{ kN/m}$
Total $F_{total_v} = F_{stem} + F_{base} + F_{moist_v} = 110.5 \text{ kN/m}$

Horizontal forces on wall

Surcharge load $F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = 3.3 \text{ kN/m}$
Moist retained soil $F_{moist_h} = \gamma_G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr'} \times h_{eff}^2 / 2 = 37.8 \text{ kN/m}$
Total $F_{total_h} = F_{sur_h} + F_{moist_h} = 41.2 \text{ kN/m}$

Check stability against sliding

Base soil resistance $F_{exc_h} = \gamma_{Gf} \times K_P \times \cos(\delta_{b,d}) \times \gamma_{b'} \times (h_{pass} + h_{base})^2 / 2 = 5.1 \text{ kN/m}$
Base friction $F_{friction} = F_{total_v} \times \tan(\delta_{bb,d}) = 63.8 \text{ kN/m}$
Resistance to sliding $F_{rest} = F_{exc_h} + F_{friction} = 68.9 \text{ kN/m}$
Factor of safety $FoS_{sl} = F_{rest} / F_{total_h} = 1.674$

PASS - Resistance to sliding is greater than sliding force

Overtipping check

Vertical forces on wall

Wall stem $F_{stem} = \gamma_{Gf} \times A_{stem} \times \gamma_{stem} = 12.2 \text{ kN/m}$

Project				Job no.	
Calcs for				Start page no./Revision 4	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Wall base

$$F_{base} = \gamma G_f \times A_{base} \times \gamma_{base} = \mathbf{15 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma G_f \times A_{moist} \times \gamma_{mr}' = \mathbf{83.2 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{moist_v} = \mathbf{110.5 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{3.3 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{37.8 \text{ kN/m}}$$

Base soil

$$F_{exc_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b' \times (h_{pass} + h_{base})^2 / 2 = \mathbf{-5.1 \text{ kN/m}}$$

Total

$$F_{total_h} = F_{sur_h} + F_{moist_h} + F_{exc_h} = \mathbf{36 \text{ kN/m}}$$

Overturning moments on wall

Surcharge load

$$M_{sur_OT} = F_{sur_h} \times X_{sur_h} = \mathbf{5 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist_OT} = F_{moist_h} \times X_{moist_h} = \mathbf{37.9 \text{ kNm/m}}$$

Total

$$M_{total_OT} = M_{sur_OT} + M_{moist_OT} = \mathbf{42.9 \text{ kNm/m}}$$

Restoring moments on wall

Wall stem

$$M_{stem_R} = F_{stem} \times X_{stem} = \mathbf{3.2 \text{ kNm/m}}$$

Wall base

$$M_{base_R} = F_{base} \times X_{base} = \mathbf{15 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist_R} = F_{moist_v} \times X_{moist_v} = \mathbf{101.3 \text{ kNm/m}}$$

Base soil

$$M_{exc_R} = -F_{exc_h} \times X_{exc_h} = \mathbf{0.5 \text{ kNm/m}}$$

Total

$$M_{total_R} = M_{stem_R} + M_{base_R} + M_{moist_R} + M_{exc_R} = \mathbf{120 \text{ kNm/m}}$$

Check stability against overturning

Factor of safety

$$FoS_{ot} = M_{total_R} / M_{total_OT} = \mathbf{2.799}$$

PASS - Maximum restoring moment is greater than overturning moment

Bearing pressure check

Vertical forces on wall

Wall stem

$$F_{stem} = \gamma G \times A_{stem} \times \gamma_{stem} = \mathbf{16.5 \text{ kN/m}}$$

Wall base

$$F_{base} = \gamma G \times A_{base} \times \gamma_{base} = \mathbf{20.3 \text{ kN/m}}$$

Surcharge load

$$F_{sur_v} = \gamma_Q \times \text{Surcharge}_Q \times h_{heel} = \mathbf{6.1 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma G \times A_{moist} \times \gamma_{mr}' = \mathbf{112.4 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{sur_v} + F_{moist_v} = \mathbf{155.2 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{3.3 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{37.8 \text{ kN/m}}$$

Base soil

$$F_{pass_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b' \times (d_{cover} + h_{base})^2 / 2 = \mathbf{-5.1 \text{ kN/m}}$$

Total

$$F_{total_h} = \max(F_{sur_h} + F_{moist_h} + F_{pass_h} - F_{total_v} \times \tan(\delta_{bb,d}), 0 \text{ kN/m}) = \mathbf{0 \text{ kN/m}}$$

Moments on wall

Wall stem

$$M_{stem} = F_{stem} \times X_{stem} = \mathbf{4.3 \text{ kNm/m}}$$

Wall base

$$M_{base} = F_{base} \times X_{base} = \mathbf{20.3 \text{ kNm/m}}$$

Surcharge load

$$M_{sur} = F_{sur_v} \times X_{sur_v} - F_{sur_h} \times X_{sur_h} = \mathbf{2.2 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist} = F_{moist_v} \times X_{moist_v} - F_{moist_h} \times X_{moist_h} = \mathbf{98.9 \text{ kNm/m}}$$

Base soil

$$M_{pass} = -F_{pass_h} \times X_{pass_h} = \mathbf{0.5 \text{ kNm/m}}$$

Total

$$M_{total} = M_{stem} + M_{base} + M_{sur} + M_{moist} + M_{pass} = \mathbf{126.2 \text{ kNm/m}}$$

Check bearing pressure

Distance to reaction

$$\bar{X} = M_{total} / F_{total_v} = \mathbf{813 \text{ mm}}$$

Project				Job no.	
Calcs for				Start page no./Revision 5	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Eccentricity of reaction	$e = \bar{x} - l_{base} / 2 = -187 \text{ mm}$
Loaded length of base	$l_{load} = 2 \times \bar{x} = 1626 \text{ mm}$
Bearing pressure at toe	$q_{toe} = F_{total_v} / l_{load} = 95.5 \text{ kN/m}^2$
Bearing pressure at heel	$q_{heel} = 0 \text{ kN/m}^2$
Effective overburden pressure	$q = (t_{base} + d_{cover}) \times \gamma_{b'} = 5.4 \text{ kN/m}^2$
Design effective overburden pressure	$q' = q / \gamma_{\gamma} = 5.4 \text{ kN/m}^2$
Bearing resistance factors	$N_q = \text{Exp}(\pi \times \tan(\phi'_{b,d})) \times (\tan(45 \text{ deg} + \phi'_{b,d} / 2))^2 = 33.296$ $N_c = (N_q - 1) \times \cot(\phi'_{b,d}) = 46.124$ $N_{\gamma} = 2 \times (N_q - 1) \times \tan(\phi'_{b,d}) = 45.228$
Foundation shape factors	$s_q = 1$ $s_{\gamma} = 1$ $s_c = 1$
Load inclination factors	$H = F_{sur_h} + F_{moist_h} + F_{pass_h} = 36 \text{ kN/m}$ $V = F_{total_v} = 155.2 \text{ kN/m}$ $m = 2$ $i_q = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^m = 0.59$ $i_{\gamma} = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^{(m+1)} = 0.453$ $i_c = i_q - (1 - i_q) / (N_c \times \tan(\phi'_{b,d})) = 0.577$
Net ultimate bearing capacity	$n_f = c'_{b,d} \times N_c \times s_c \times i_c + q' \times N_q \times s_q \times i_q + 0.5 \times \gamma_{b'} \times l_{load} \times N_{\gamma} \times s_{\gamma} \times i_{\gamma} = 405.6 \text{ kN/m}^2$
Factor of safety	$FoS_{bp} = n_f / \max(q_{toe}, q_{heel}) = 4.248$ PASS - Allowable bearing pressure exceeds maximum applied bearing pressure

Design approach 1

Partial factors on actions - Table A.3 - Combination 2

Partial factor set	A2
Permanent unfavourable action	$\gamma_G = 1.000$
Permanent favourable action	$\gamma_{Gf} = 1.000$
Variable unfavourable action	$\gamma_Q = 1.300$
Variable favourable action	$\gamma_{Qf} = 0.000$

Partial factors for soil parameters – Table A.4 - Combination 2

Soil parameter set	M2
Angle of shearing resistance	$\gamma_{\phi'} = 1.25$
Effective cohesion	$\gamma_{c'} = 1.25$
Weight density	$\gamma_{\gamma} = 1.00$

Retained soil properties

Design moist density	$\gamma_{mr}' = \gamma_{mr} / \gamma_{\gamma} = 21 \text{ kN/m}^3$
Design saturated density	$\gamma_{sr}' = \gamma_{sr} / \gamma_{\gamma} = 23 \text{ kN/m}^3$
Design effective shear resistance angle	$\phi'_{r,d} = \text{atan}(\tan(\phi'_{r,k}) / \gamma_{\phi'}) = 29.3 \text{ deg}$
Design wall friction angle	$\delta_{r,d} = \text{atan}(\tan(\delta_{r,k}) / \gamma_{\phi'}) = 14.2 \text{ deg}$

Base soil properties

Design soil density	$\gamma_{b'} = \gamma_b / \gamma_{\gamma} = 18 \text{ kN/m}^3$
Design effective shear resistance angle	$\phi'_{b,d} = \text{atan}(\tan(\phi'_{b,k}) / \gamma_{\phi'}) = 29.3 \text{ deg}$
Design wall friction angle	$\delta_{b,d} = \text{atan}(\tan(\delta_{b,k}) / \gamma_{\phi'}) = 12.1 \text{ deg}$
Design base friction angle	$\delta_{bb,d} = \text{atan}(\tan(\delta_{bb,k}) / \gamma_{\phi'}) = 24.8 \text{ deg}$

Project				Job no.	
Calcs for				Start page no./Revision 6	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Design effective cohesion

$$c'_{b,d} = c'_{b,k} / \gamma_c = 0 \text{ kN/m}^2$$

Using Coulomb theory

Active pressure coefficient

$$K_A = \sin(\alpha + \phi'_{r,d})^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta_{r,d}) \times [1 + \sqrt{[\sin(\phi'_{r,d} + \delta_{r,d}) \times \sin(\phi'_{r,d} - \beta) / (\sin(\alpha - \delta_{r,d}) \times \sin(\alpha + \beta))]}])^2 = 0.411$$

Passive pressure coefficient

$$K_P = \sin(90 - \phi'_{b,d})^2 / (\sin(90 + \delta_{b,d}) \times [1 - \sqrt{[\sin(\phi'_{b,d} + \delta_{b,d}) \times \sin(\phi'_{b,d}) / (\sin(90 + \delta_{b,d}))]}])^2 = 4.303$$

Sliding check

Vertical forces on wall

Wall stem

$$F_{stem} = \gamma G_f \times A_{stem} \times \gamma_{stem} = 12.2 \text{ kN/m}$$

Wall base

$$F_{base} = \gamma G_f \times A_{base} \times \gamma_{base} = 15 \text{ kN/m}$$

Moist retained soil

$$F_{moist_v} = \gamma G_f \times A_{moist} \times \gamma_{mr'} = 83.2 \text{ kN/m}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{moist_v} = 110.5 \text{ kN/m}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma Q \times \text{Surcharge}_Q \times h_{eff} = 3.9 \text{ kN/m}$$

Moist retained soil

$$F_{moist_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr'} \times h_{eff}^2 / 2 = 37.8 \text{ kN/m}$$

Total

$$F_{total_h} = F_{sur_h} + F_{moist_h} = 41.7 \text{ kN/m}$$

Check stability against sliding

Base soil resistance

$$F_{exc_h} = \gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b' \times (h_{pass} + h_{base})^2 / 2 = 3.4 \text{ kN/m}$$

Base friction

$$F_{friction} = F_{total_v} \times \tan(\delta_{bb,d}) = 51 \text{ kN/m}$$

Resistance to sliding

$$F_{rest} = F_{exc_h} + F_{friction} = 54.4 \text{ kN/m}$$

Factor of safety

$$FoS_{sl} = F_{rest} / F_{total_h} = 1.306$$

PASS - Resistance to sliding is greater than sliding force

Overtipping check

Vertical forces on wall

Wall stem

$$F_{stem} = \gamma G_f \times A_{stem} \times \gamma_{stem} = 12.2 \text{ kN/m}$$

Wall base

$$F_{base} = \gamma G_f \times A_{base} \times \gamma_{base} = 15 \text{ kN/m}$$

Moist retained soil

$$F_{moist_v} = \gamma G_f \times A_{moist} \times \gamma_{mr'} = 83.2 \text{ kN/m}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{moist_v} = 110.5 \text{ kN/m}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma Q \times \text{Surcharge}_Q \times h_{eff} = 3.9 \text{ kN/m}$$

Moist retained soil

$$F_{moist_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr'} \times h_{eff}^2 / 2 = 37.8 \text{ kN/m}$$

Base soil

$$F_{exc_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b' \times (h_{pass} + h_{base})^2 / 2 = -3.4 \text{ kN/m}$$

Total

$$F_{total_h} = F_{sur_h} + F_{moist_h} + F_{exc_h} = 38.3 \text{ kN/m}$$

Overtipping moments on wall

Surcharge load

$$M_{sur_OT} = F_{sur_h} \times X_{sur_h} = 5.8 \text{ kNm/m}$$

Moist retained soil

$$M_{moist_OT} = F_{moist_h} \times X_{moist_h} = 37.8 \text{ kNm/m}$$

Total

$$M_{total_OT} = M_{sur_OT} + M_{moist_OT} = 43.7 \text{ kNm/m}$$

Restoring moments on wall

Wall stem

$$M_{stem_R} = F_{stem} \times X_{stem} = 3.2 \text{ kNm/m}$$

Wall base

$$M_{base_R} = F_{base} \times X_{base} = 15 \text{ kNm/m}$$

Moist retained soil

$$M_{moist_R} = F_{moist_v} \times X_{moist_v} = 101.3 \text{ kNm/m}$$

Base soil

$$M_{exc_R} = -F_{exc_h} \times X_{exc_h} = 0.3 \text{ kNm/m}$$

Total

$$M_{total_R} = M_{stem_R} + M_{base_R} + M_{moist_R} + M_{exc_R} = 119.8 \text{ kNm/m}$$

Project				Job no.	
Calcs for				Start page no./Revision 7	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Check stability against overturning

Factor of safety

$$FoS_{ot} = M_{total_R} / M_{total_OT} = \mathbf{2.745}$$

PASS - Maximum restoring moment is greater than overturning moment

Bearing pressure check

Vertical forces on wall

Wall stem

$$F_{stem} = \gamma_G \times A_{stem} \times \gamma_{stem} = \mathbf{12.2 \text{ kN/m}}$$

Wall base

$$F_{base} = \gamma_G \times A_{base} \times \gamma_{base} = \mathbf{15 \text{ kN/m}}$$

Surcharge load

$$F_{sur_v} = \gamma_Q \times \text{Surcharge}_Q \times l_{heel} = \mathbf{5.3 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma_G \times A_{moist} \times \gamma_{mr}' = \mathbf{83.2 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{sur_v} + F_{moist_v} = \mathbf{115.7 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{3.9 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma_G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{37.8 \text{ kN/m}}$$

Base soil

$$F_{pass_h} = -\gamma_G \times K_P \times \cos(\delta_{b,d}) \times \gamma_{b'} \times (d_{cover} + h_{base})^2 / 2 = \mathbf{-3.4 \text{ kN/m}}$$

Total

$$F_{total_h} = \max(F_{sur_h} + F_{moist_h} + F_{pass_h} - F_{total_v} \times \tan(\delta_{bb,d}), 0 \text{ kN/m}) = \mathbf{0 \text{ kN/m}}$$

Moments on wall

Wall stem

$$M_{stem} = F_{stem} \times X_{stem} = \mathbf{3.2 \text{ kNm/m}}$$

Wall base

$$M_{base} = F_{base} \times X_{base} = \mathbf{15 \text{ kNm/m}}$$

Surcharge load

$$M_{sur} = F_{sur_v} \times X_{sur_v} - F_{sur_h} \times X_{sur_h} = \mathbf{0.4 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist} = F_{moist_v} \times X_{moist_v} - F_{moist_h} \times X_{moist_h} = \mathbf{63.5 \text{ kNm/m}}$$

Base soil

$$M_{pass} = -F_{pass_h} \times X_{pass_h} = \mathbf{0.3 \text{ kNm/m}}$$

Total

$$M_{total} = M_{stem} + M_{base} + M_{sur} + M_{moist} + M_{pass} = \mathbf{82.4 \text{ kNm/m}}$$

Check bearing pressure

Distance to reaction

$$\bar{x} = M_{total} / F_{total_v} = \mathbf{712 \text{ mm}}$$

Eccentricity of reaction

$$e = \bar{x} - l_{base} / 2 = \mathbf{-288 \text{ mm}}$$

Loaded length of base

$$l_{load} = 2 \times \bar{x} = \mathbf{1425 \text{ mm}}$$

Bearing pressure at toe

$$q_{toe} = F_{total_v} / l_{load} = \mathbf{81.2 \text{ kN/m}^2}$$

Bearing pressure at heel

$$q_{heel} = \mathbf{0 \text{ kN/m}^2}$$

Effective overburden pressure

$$q = (t_{base} + d_{cover}) \times \gamma_{b'} = \mathbf{5.4 \text{ kN/m}^2}$$

Design effective overburden pressure

$$q' = q / \gamma_r = \mathbf{5.4 \text{ kN/m}^2}$$

Bearing resistance factors

$$N_q = \text{Exp}(\pi \times \tan(\phi'_{b,d})) \times (\tan(45 \text{ deg} + \phi'_{b,d} / 2))^2 = \mathbf{16.921}$$

$$N_c = (N_q - 1) \times \cot(\phi'_{b,d}) = \mathbf{28.422}$$

$$N_\gamma = 2 \times (N_q - 1) \times \tan(\phi'_{b,d}) = \mathbf{17.837}$$

Foundation shape factors

$$s_q = 1$$

$$s_\gamma = 1$$

$$s_c = 1$$

Load inclination factors

$$H = F_{sur_h} + F_{moist_h} + F_{pass_h} = \mathbf{38.3 \text{ kN/m}}$$

$$V = F_{total_v} = \mathbf{115.7 \text{ kN/m}}$$

$$m = 2$$

$$i_q = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^m = \mathbf{0.448}$$

$$i_\gamma = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^{(m+1)} = \mathbf{0.3}$$

$$i_c = i_q - (1 - i_q) / (N_c \times \tan(\phi'_{b,d})) = \mathbf{0.414}$$

Net ultimate bearing capacity

Project				Job no.	
Calcs for				Start page no./Revision 8	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

$$n_f = c'_{b,d} \times N_c \times s_c \times i_c + q' \times N_q \times s_q \times i_q + 0.5 \times \gamma'_b \times l_{load} \times N_\gamma \times s_\gamma \times i_\gamma = \mathbf{109.6 \text{ kN/m}^2}$$

Factor of safety

$$FoS_{bp} = n_f / \max(q_{toe}, q_{heel}) = \mathbf{1.349}$$

PASS - Allowable bearing pressure exceeds maximum applied bearing pressure

RETAINING WALL DESIGN

In accordance with EN1992-1-1:2004 incorporating Corrigendum dated January 2008 and the UK National Annex incorporating National Amendment No.1

Tedds calculation version 2.9.22

Concrete details - Table 3.1 - Strength and deformation characteristics for concrete

Concrete strength class	C30/37
Characteristic compressive cylinder strength	$f_{ck} = \mathbf{30 \text{ N/mm}^2}$
Characteristic compressive cube strength	$f_{ck,cube} = \mathbf{37 \text{ N/mm}^2}$
Mean value of compressive cylinder strength	$f_{cm} = f_{ck} + 8 \text{ N/mm}^2 = \mathbf{38 \text{ N/mm}^2}$
Mean value of axial tensile strength	$f_{ctm} = 0.3 \text{ N/mm}^2 \times (f_{ck} / 1 \text{ N/mm}^2)^{2/3} = \mathbf{2.9 \text{ N/mm}^2}$
5% fractile of axial tensile strength	$f_{ctk,0.05} = 0.7 \times f_{ctm} = \mathbf{2.0 \text{ N/mm}^2}$
Secant modulus of elasticity of concrete	$E_{cm} = 22 \text{ kN/mm}^2 \times (f_{cm} / 10 \text{ N/mm}^2)^{0.3} = \mathbf{32837 \text{ N/mm}^2}$
Partial factor for concrete - Table 2.1N	$\gamma_C = \mathbf{1.50}$
Compressive strength coefficient - cl.3.1.6(1)	$\alpha_{cc} = \mathbf{0.85}$
Design compressive concrete strength - exp.3.15	$f_{cd} = \alpha_{cc} \times f_{ck} / \gamma_C = \mathbf{17.0 \text{ N/mm}^2}$
Maximum aggregate size	$h_{agg} = \mathbf{20 \text{ mm}}$
Ultimate strain - Table 3.1	$\epsilon_{cu2} = \mathbf{0.0035}$
Shortening strain - Table 3.1	$\epsilon_{cu3} = \mathbf{0.0035}$
Effective compression zone height factor	$\lambda = \mathbf{0.80}$
Effective strength factor	$\eta = \mathbf{1.00}$
Bending coefficient k_1	$K_1 = \mathbf{0.40}$
Bending coefficient k_2	$K_2 = 1.00 \times (0.6 + 0.0014/\epsilon_{cu2}) = \mathbf{1.00}$
Bending coefficient k_3	$K_3 = \mathbf{0.40}$
Bending coefficient k_4	$K_4 = 1.00 \times (0.6 + 0.0014/\epsilon_{cu2}) = \mathbf{1.00}$







Reinforcement details

Characteristic yield strength of reinforcement	$f_{yk} = \mathbf{500 \text{ N/mm}^2}$
Modulus of elasticity of reinforcement	$E_s = \mathbf{200000 \text{ N/mm}^2}$
Partial factor for reinforcing steel - Table 2.1N	$\gamma_S = \mathbf{1.15}$
Design yield strength of reinforcement	$f_{yd} = f_{yk} / \gamma_S = \mathbf{435 \text{ N/mm}^2}$

Cover to reinforcement

Front face of stem	$c_{sf} = \mathbf{40 \text{ mm}}$
Rear face of stem	$c_{sr} = \mathbf{50 \text{ mm}}$
Top face of base	$c_{bt} = \mathbf{50 \text{ mm}}$
Bottom face of base	$c_{bb} = \mathbf{75 \text{ mm}}$

Project				Job no.	
Calcs for				Start page no./Revision 9	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date



Check stem design at base of stem

Depth of section

$h = 225 \text{ mm}$

Rectangular section in flexure - Section 6.1

Design bending moment combination 2

$M = 17.4 \text{ kNm/m}$

Depth to tension reinforcement

$d = h - C_{sr} - \phi_{sr} / 2 = 169 \text{ mm}$

$K = M / (d^2 \times f_{ck}) = 0.020$

$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$

$K' = 0.207$

$K' > K$ - No compression reinforcement is required

Lever arm

$z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 161 \text{ mm}$

Depth of neutral axis

$x = 2.5 \times (d - z) = 21 \text{ mm}$

Area of tension reinforcement required

$A_{sr,req} = M / (f_{yd} \times z) = 250 \text{ mm}^2/\text{m}$

Tension reinforcement provided

12 dia.bars @ 200 c/c

Area of tension reinforcement provided

$A_{sr,prov} = \pi \times \phi_{sr}^2 / (4 \times s_{sr}) = 565 \text{ mm}^2/\text{m}$



Project				Job no.	
Calcs for				Start page no./Revision 10	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Minimum area of reinforcement - exp.9.1N

$$A_{sr.min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = \mathbf{255 \text{ mm}^2/\text{m}}$$

Maximum area of reinforcement - cl.9.2.1.1(3)

$$A_{sr.max} = 0.04 \times h = \mathbf{9000 \text{ mm}^2/\text{m}}$$

$$\max(A_{sr.req}, A_{sr.min}) / A_{sr.prov} = \mathbf{0.45}$$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Deflection control - Section 7.4

Reference reinforcement ratio

$$\rho_0 = \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} / 1000 = \mathbf{0.005}$$

Required tension reinforcement ratio

$$\rho = A_{sr.req} / d = \mathbf{0.001}$$

Required compression reinforcement ratio

$$\rho' = A_{sr.2.req} / d_2 = \mathbf{0.000}$$

Structural system factor - Table 7.4N

$$K_b = \mathbf{0.4}$$

Reinforcement factor - exp.7.17

$$K_s = \min(500 \text{ N/mm}^2 / (f_{yk} \times A_{sr.req} / A_{sr.prov}), 1.5) = \mathbf{1.5}$$

Limiting span to depth ratio - exp.7.16.a

$$\min(K_s \times K_b \times [11 + 1.5 \times \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} \times \rho_0 / \rho + 3.2 \times \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} \times (\rho_0 / \rho - 1)^{3/2}], 40 \times K_b) = \mathbf{16}$$

Actual span to depth ratio

$$h_{stem} / d = \mathbf{12.9}$$

PASS - Span to depth ratio is less than deflection control limit

Crack control - Section 7.3

Limiting crack width

$$w_{max} = \mathbf{0.3 \text{ mm}}$$

Variable load factor - EN1990 – Table A1.1

$$\psi_2 = \mathbf{0.6}$$

Serviceability bending moment

$$M_{sls} = \mathbf{11.7 \text{ kNm/m}}$$

Tensile stress in reinforcement

$$\sigma_s = M_{sls} / (A_{sr.prov} \times z) = \mathbf{129 \text{ N/mm}^2}$$

Load duration

Long term

Load duration factor

$$k_t = \mathbf{0.4}$$

Effective area of concrete in tension

$$A_{c.eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$$

$$A_{c.eff} = \mathbf{67958 \text{ mm}^2/\text{m}}$$

Mean value of concrete tensile strength

$$f_{ct.eff} = f_{ctm} = \mathbf{2.9 \text{ N/mm}^2}$$

Reinforcement ratio

$$\rho_{p.eff} = A_{sr.prov} / A_{c.eff} = \mathbf{0.008}$$

Modular ratio

$$\alpha_e = E_s / E_{cm} = \mathbf{6.091}$$

Bond property coefficient

$$k_1 = \mathbf{0.8}$$

Strain distribution coefficient

$$k_2 = \mathbf{0.5}$$

$$k_3 = \mathbf{3.4}$$

$$k_4 = \mathbf{0.425}$$

Maximum crack spacing - exp.7.11

$$s_{r.max} = k_3 \times C_{sr} + k_1 \times k_2 \times k_4 \times \phi_{sr} / \rho_{p.eff} = \mathbf{415 \text{ mm}}$$

Maximum crack width - exp.7.8

$$w_k = s_{r.max} \times \max(\sigma_s - k_t \times (f_{ct.eff} / \rho_{p.eff}) \times (1 + \alpha_e \times \rho_{p.eff}), 0.6 \times \sigma_s) / E_s$$

$$w_k = \mathbf{0.161 \text{ mm}}$$

$$w_k / w_{max} = \mathbf{0.535}$$

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$$V = \mathbf{22.6 \text{ kN/m}}$$

$$C_{Rd,c} = 0.18 / \gamma_C = \mathbf{0.120}$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = \mathbf{2.000}$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{sr.prov} / d, 0.02) = \mathbf{0.003}$$

$$v_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = \mathbf{0.542 \text{ N/mm}^2}$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, v_{min}) \times d$$

$$V_{Rd,c} = \mathbf{91.6 \text{ kN/m}}$$

$$V / V_{Rd,c} = \mathbf{0.247}$$

PASS - Design shear resistance exceeds design shear force



Project				Job no.	
Calcs for				Start page no./Revision 11	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Horizontal reinforcement parallel to face of stem - Section 9.6

Minimum area of reinforcement – cl.9.6.3(1) $A_{sx.req} = \max(0.25 \times A_{sr.prov}, 0.001 \times t_{stem}) = 225 \text{ mm}^2/\text{m}$

Maximum spacing of reinforcement – cl.9.6.3(2) $s_{sx.max} = 400 \text{ mm}$

Transverse reinforcement provided 10 dia.bars @ 200 c/c

Area of transverse reinforcement provided $A_{sx.prov} = \pi \times \phi_{sx}^2 / (4 \times s_{sx}) = 393 \text{ mm}^2/\text{m}$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Check base design at toe

Depth of section $h = 300 \text{ mm}$

Rectangular section in flexure - Section 6.1

Design bending moment combination 1 $M = 2.5 \text{ kNm/m}$

Depth to tension reinforcement $d = h - c_{bb} - \phi_{bb} / 2 = 219 \text{ mm}$

$K = M / (d^2 \times f_{ck}) = 0.002$

$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$

$K' = 0.207$

$K' > K$ - No compression reinforcement is required

Lever arm $z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 208 \text{ mm}$

Depth of neutral axis $x = 2.5 \times (d - z) = 27 \text{ mm}$

Area of tension reinforcement required $A_{bb.req} = M / (f_{yd} \times z) = 27 \text{ mm}^2/\text{m}$

Tension reinforcement provided 12 dia.bars @ 200 c/c

Area of tension reinforcement provided $A_{bb.prov} = \pi \times \phi_{bb}^2 / (4 \times s_{bb}) = 565 \text{ mm}^2/\text{m}$

Minimum area of reinforcement - exp.9.1N $A_{bb.min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = 330 \text{ mm}^2/\text{m}$

Maximum area of reinforcement - cl.9.2.1.1(3) $A_{bb.max} = 0.04 \times h = 12000 \text{ mm}^2/\text{m}$

$\max(A_{bb.req}, A_{bb.min}) / A_{bb.prov} = 0.583$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Crack control - Section 7.3

Limiting crack width $w_{max} = 0.3 \text{ mm}$

Variable load factor - EN1990 – Table A1.1 $\psi_2 = 0.6$

Serviceability bending moment $M_{sls} = 1.8 \text{ kNm/m}$

Tensile stress in reinforcement $\sigma_s = M_{sls} / (A_{bb.prov} \times z) = 15.4 \text{ N/mm}^2$

Load duration Long term

Load duration factor $k_t = 0.4$

Effective area of concrete in tension $A_{c.eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$

$A_{c.eff} = 90875 \text{ mm}^2/\text{m}$

Mean value of concrete tensile strength $f_{ct.eff} = f_{ctm} = 2.9 \text{ N/mm}^2$

Reinforcement ratio $\rho_{p.eff} = A_{bb.prov} / A_{c.eff} = 0.006$

Modular ratio $\alpha_e = E_s / E_{cm} = 6.091$

Bond property coefficient $k_1 = 0.8$

Strain distribution coefficient $k_2 = 0.5$

$k_3 = 3.4$

$k_4 = 0.425$

Maximum crack spacing - exp.7.11 $s_{r.max} = k_3 \times c_{bb} + k_1 \times k_2 \times k_4 \times \phi_{bb} / \rho_{p.eff} = 583 \text{ mm}$

Maximum crack width - exp.7.8 $w_k = s_{r.max} \times \max(\sigma_s - k_t \times (f_{ct.eff} / \rho_{p.eff}) \times (1 + \alpha_e \times \rho_{p.eff}), 0.6 \times \sigma_s) / E_s$

$w_k = 0.027 \text{ mm}$

$w_k / w_{max} = 0.09$

PASS - Maximum crack width is less than limiting crack width



Project				Job no.	
Calcs for				Start page no./Revision 12	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Rectangular section in shear - Section 6.2

Design shear force

$$V = 19.5 \text{ kN/m}$$

$$C_{Rd,c} = 0.18 / \gamma_C = 0.120$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = 1.956$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{bb,prov} / d, 0.02) = 0.003$$

$$v_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = 0.524 \text{ N/mm}^2$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, v_{min}) \times d$$

$$V_{Rd,c} = 114.8 \text{ kN/m}$$

$$V / V_{Rd,c} = 0.170$$

PASS - Design shear resistance exceeds design shear force

Check base design at heel

Depth of section

$$h = 300 \text{ mm}$$

Rectangular section in flexure - Section 6.1

Design bending moment combination 2

$$M = 15.7 \text{ kNm/m}$$

Depth to tension reinforcement

$$d = h - c_{bt} - \phi_{bt} / 2 = 244 \text{ mm}$$

$$K = M / (d^2 \times f_{ck}) = 0.009$$

$$K' = (2 \times \eta \times \alpha_{cc} / \gamma_C) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$$

$$K' = 0.207$$

$K' > K$ - No compression reinforcement is required

Lever arm

$$z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_C))^{0.5}, 0.95) \times d = 232 \text{ mm}$$

Depth of neutral axis

$$x = 2.5 \times (d - z) = 31 \text{ mm}$$

Area of tension reinforcement required

$$A_{bt,req} = M / (f_{yd} \times z) = 156 \text{ mm}^2/\text{m}$$

Tension reinforcement provided

$$12 \text{ dia. bars @ } 200 \text{ c/c}$$

Area of tension reinforcement provided

$$A_{bt,prov} = \pi \times \phi_{bt}^2 / (4 \times s_{bt}) = 565 \text{ mm}^2/\text{m}$$

Minimum area of reinforcement - exp.9.1N

$$A_{bt,min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = 368 \text{ mm}^2/\text{m}$$

Maximum area of reinforcement - cl.9.2.1.1(3)

$$A_{bt,max} = 0.04 \times h = 12000 \text{ mm}^2/\text{m}$$

$$\max(A_{bt,req}, A_{bt,min}) / A_{bt,prov} = 0.65$$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Crack control - Section 7.3

Limiting crack width

$$w_{max} = 0.3 \text{ mm}$$

Variable load factor - EN1990 – Table A1.1

$$\psi_2 = 0.6$$

Serviceability bending moment

$$M_{sls} = 9.7 \text{ kNm/m}$$

Tensile stress in reinforcement

$$\sigma_s = M_{sls} / (A_{bt,prov} \times z) = 73.7 \text{ N/mm}^2$$

Load duration

Long term

Load duration factor

$$k_t = 0.4$$

Effective area of concrete in tension

$$A_{c,eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$$

$$A_{c,eff} = 89833 \text{ mm}^2/\text{m}$$

Mean value of concrete tensile strength

$$f_{ct,eff} = f_{ctm} = 2.9 \text{ N/mm}^2$$

Reinforcement ratio

$$\rho_{p,eff} = A_{bt,prov} / A_{c,eff} = 0.006$$

Modular ratio

$$\alpha_e = E_s / E_{cm} = 6.091$$

Bond property coefficient

$$k_1 = 0.8$$

Strain distribution coefficient

$$k_2 = 0.5$$

$$k_3 = 3.4$$

$$k_4 = 0.425$$

Maximum crack spacing - exp.7.11

$$s_{r,max} = k_3 \times c_{bt} + k_1 \times k_2 \times k_4 \times \phi_{bt} / \rho_{p,eff} = 494 \text{ mm}$$

Project				Job no.	
Calcs for				Start page no./Revision 13	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Maximum crack width - exp.7.8

$$W_k = S_{r,max} \times \max(\sigma_s - k_t \times (f_{ct,eff} / \rho_{p,eff}) \times (1 + \alpha_e \times \rho_{p,eff}), 0.6 \times \sigma_s) / E_s$$

$$W_k = \mathbf{0.109 \text{ mm}}$$

$$W_k / W_{max} = \mathbf{0.364}$$

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$$V = \mathbf{13.2 \text{ kN/m}}$$

$$C_{Rd,c} = 0.18 / \gamma_c = \mathbf{0.120}$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = \mathbf{1.905}$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{bt,prov} / d, 0.02) = \mathbf{0.002}$$

$$v_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = \mathbf{0.504 \text{ N/mm}^2}$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, v_{min}) \times d$$

$$V_{Rd,c} = \mathbf{123 \text{ kN/m}}$$

$$V / V_{Rd,c} = \mathbf{0.107}$$

PASS - Design shear resistance exceeds design shear force

Secondary transverse reinforcement to base - Section 9.3

Minimum area of reinforcement – cl.9.3.1.1(2)

$$A_{bx,req} = 0.2 \times A_{bb,prov} = \mathbf{113 \text{ mm}^2/\text{m}}$$

Maximum spacing of reinforcement – cl.9.3.1.1(3)

$$s_{bx,max} = \mathbf{450 \text{ mm}}$$


Transverse reinforcement provided

$$\mathbf{10 \text{ dia. bars @ } 200 \text{ c/c}}$$

Area of transverse reinforcement provided

$$A_{bx,prov} = \pi \times \phi_{bx}^2 / (4 \times s_{bx}) = \mathbf{393 \text{ mm}^2/\text{m}}$$

PASS - Area of reinforcement provided is greater than area of reinforcement required



Reinforcement details

Project				Job no.	
Calcs for				Start page no./Revision 1	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

RETAINING WALL ANALYSIS

In accordance with EN1997-1:2004 incorporating Corrigendum dated February 2009 and the UK National Annex incorporating Corrigendum No.1

Tedds calculation version 2.9.22

Analysis summary

Design summary

Overall design utilisation 0.796

Overall design status Pass

Description	Unit	Capacity	Applied	F o S	Result
Sliding stability	kN/m	46.1	36.2	1.274	PASS
Overturning stability	kNm/m	90.6	35.3	2.566	PASS
Bearing pressure	kN/m ²	98.1	78.1	1.256	PASS

Design summary

Description	Unit	Provided	Required	Utilisation	Result
Shear resistance	kN/m	114.8	16.8	0.146	PASS
Base top face - Flexural reinforcement	mm ² /m	565.5	367.5	0.650	PASS
Base bottom face - Flexural reinforcement	mm ² /m	565.5	329.8	0.583	PASS
Base - Shear resistance	kN/m	114.8	16.8	0.146	PASS
Min. transverse stem reinf.	mm ² /m	392.7	225.0	0.573	PASS
Min. transverse base reinf.	mm ² /m	392.7	113.1	0.288	PASS

Retaining wall details

Stem type	Cantilever
Stem height	$h_{\text{stem}} = 2025$ mm
Stem thickness	$t_{\text{stem}} = 225$ mm
Angle to rear face of stem	$\alpha = 90$ deg
Stem density	$\gamma_{\text{stem}} = 25$ kN/m ³
Toe length	$l_{\text{toe}} = 150$ mm
Heel length	$l_{\text{heel}} = 1425$ mm
Base thickness	$t_{\text{base}} = 300$ mm
Base density	$\gamma_{\text{base}} = 25$ kN/m ³
Height of retained soil	$h_{\text{ret}} = 2025$ mm
Angle of soil surface	$\beta = 18$ deg
Depth of cover	$d_{\text{cover}} = 0$ mm

Retained soil properties

Soil type	Medium dense well graded sand
Moist density	$\gamma_{\text{mr}} = 21$ kN/m ³
Saturated density	$\gamma_{\text{sr}} = 23$ kN/m ³
Characteristic effective shear resistance angle	$\phi'_{r,k} = 35$ deg
Characteristic wall friction angle	$\delta_{r,k} = 17.5$ deg

Base soil properties


Soil type	Medium dense well graded sand
Soil density	$\gamma_b = 18$ kN/m ³
Characteristic cohesion	$c'_{b,k} = 0$ kN/m ²
Characteristic effective shear resistance angle	$\phi'_{b,k} = 35$ deg
Characteristic wall friction angle	$\delta_{b,k} = 15$ deg
Characteristic base friction angle	$\delta_{bb,k} = 30$ deg

Project				Job no.	
Calcs for				Start page no./Revision 2	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Loading details

Variable surcharge load

Surcharge₀ = 2.5 kN/m²



General arrangement - sketch pressures relate to bearing check

Calculate retaining wall geometry

Base length	$l_{base} = l_{toe} + t_{stem} + l_{heel} = 1800 \text{ mm}$
Moist soil height	$h_{moist} = h_{soil} = 2025 \text{ mm}$
Length of surcharge load	$l_{sur} = l_{heel} = 1425 \text{ mm}$
- Distance to vertical component	$x_{sur_v} = l_{base} - l_{heel} / 2 = 1088 \text{ mm}$
Effective height of wall	$h_{eff} = h_{base} + d_{cover} + h_{ret} + l_{sur} \times \tan(\beta) = 2788 \text{ mm}$
- Distance to horizontal component	$x_{sur_h} = h_{eff} / 2 = 1394 \text{ mm}$
Area of wall stem	$A_{stem} = h_{stem} \times t_{stem} = 0.456 \text{ m}^2$
- Distance to vertical component	$x_{stem} = l_{toe} + t_{stem} / 2 = 263 \text{ mm}$
Area of wall base	$A_{base} = l_{base} \times t_{base} = 0.54 \text{ m}^2$
- Distance to vertical component	$x_{base} = l_{base} / 2 = 900 \text{ mm}$
Area of moist soil	$A_{moist} = h_{moist} \times l_{heel} + \tan(\beta) \times l_{heel}^2 / 2 = 3.216 \text{ m}^2$
- Distance to vertical component	$x_{moist_v} = l_{base} - (h_{moist} \times l_{heel}^2 / 2 + \tan(\beta) \times l_{heel}^3 / 6) / A_{moist} = 1112 \text{ mm}$
- Distance to horizontal component	$x_{moist_h} = h_{eff} / 3 = 929 \text{ mm}$

Design approach 1

Partial factors on actions - Table A.3 - Combination 1

Partial factor set	A1
Permanent unfavourable action	$\gamma_G = 1.350$
Permanent favourable action	$\gamma_{Gf} = 1.000$

Project				Job no.	
Calcs for				Start page no./Revision 3	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Variable unfavourable action $\gamma_Q = 1.500$
Variable favourable action $\gamma_{Qf} = 0.000$

Partial factors for soil parameters – Table A.4 - Combination 1

Soil parameter set M1
Angle of shearing resistance $\gamma_{\phi'} = 1.00$
Effective cohesion $\gamma_{c'} = 1.00$
Weight density $\gamma_{\gamma} = 1.00$

Retained soil properties

Design moist density $\gamma_{mr'} = \gamma_{mr} / \gamma_{\gamma} = 21 \text{ kN/m}^3$
Design saturated density $\gamma_{sr'} = \gamma_{sr} / \gamma_{\gamma} = 23 \text{ kN/m}^3$
Design effective shear resistance angle $\phi'_{r,d} = \text{atan}(\tan(\phi'_{r,k}) / \gamma_{\phi'}) = 35 \text{ deg}$
Design wall friction angle $\delta_{r,d} = \text{atan}(\tan(\delta_{r,k}) / \gamma_{\phi'}) = 17.5 \text{ deg}$

Base soil properties

Design soil density $\gamma_{b'} = \gamma_b / \gamma_{\gamma} = 18 \text{ kN/m}^3$
Design effective shear resistance angle $\phi'_{b,d} = \text{atan}(\tan(\phi'_{b,k}) / \gamma_{\phi'}) = 35 \text{ deg}$
Design wall friction angle $\delta_{b,d} = \text{atan}(\tan(\delta_{b,k}) / \gamma_{\phi'}) = 15 \text{ deg}$
Design base friction angle $\delta_{bb,d} = \text{atan}(\tan(\delta_{bb,k}) / \gamma_{\phi'}) = 30 \text{ deg}$
Design effective cohesion $c'_{b,d} = c'_{b,k} / \gamma_{c'} = 0 \text{ kN/m}^2$

Using Coulomb theory

Active pressure coefficient $K_A = \sin(\alpha + \phi'_{r,d})^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta_{r,d}) \times [1 + \sqrt{[\sin(\phi'_{r,d} + \delta_{r,d}) \times \sin(\phi'_{r,d} - \beta) / (\sin(\alpha - \delta_{r,d}) \times \sin(\alpha + \beta))]}])^2 = 0.310$
Passive pressure coefficient $K_P = \sin(90 - \phi'_{b,d})^2 / (\sin(90 + \delta_{b,d}) \times [1 - \sqrt{[\sin(\phi'_{b,d} + \delta_{b,d}) \times \sin(\phi'_{b,d}) / (\sin(90 + \delta_{b,d}))]}])^2 = 6.555$

Sliding check

Vertical forces on wall

Wall stem $F_{\text{stem}} = \gamma_{Gf} \times A_{\text{stem}} \times \gamma_{\text{stem}} = 11.4 \text{ kN/m}$
Wall base $F_{\text{base}} = \gamma_{Gf} \times A_{\text{base}} \times \gamma_{\text{base}} = 13.5 \text{ kN/m}$
Moist retained soil $F_{\text{moist}_v} = \gamma_{Gf} \times A_{\text{moist}} \times \gamma_{mr'} = 67.5 \text{ kN/m}$
Total $F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} = 92.4 \text{ kN/m}$

Horizontal forces on wall

Surcharge load $F_{\text{sur}_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{\text{eff}} = 3.1 \text{ kN/m}$
Moist retained soil $F_{\text{moist}_h} = \gamma_G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr'} \times h_{\text{eff}}^2 / 2 = 32.6 \text{ kN/m}$
Total $F_{\text{total}_h} = F_{\text{sur}_h} + F_{\text{moist}_h} = 35.7 \text{ kN/m}$

Check stability against sliding

Base soil resistance $F_{\text{exc}_h} = \gamma_{Gf} \times K_P \times \cos(\delta_{b,d}) \times \gamma_{b'} \times (h_{\text{pass}} + h_{\text{base}})^2 / 2 = 5.1 \text{ kN/m}$
Base friction $F_{\text{friction}} = F_{\text{total}_v} \times \tan(\delta_{bb,d}) = 53.4 \text{ kN/m}$
Resistance to sliding $F_{\text{rest}} = F_{\text{exc}_h} + F_{\text{friction}} = 58.5 \text{ kN/m}$
Factor of safety $FoS_{\text{sl}} = F_{\text{rest}} / F_{\text{total}_h} = 1.638$

PASS - Resistance to sliding is greater than sliding force

Overtipping check

Vertical forces on wall

Wall stem $F_{\text{stem}} = \gamma_{Gf} \times A_{\text{stem}} \times \gamma_{\text{stem}} = 11.4 \text{ kN/m}$

Project				Job no.	
Calcs for				Start page no./Revision 4	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Wall base

$$F_{base} = \gamma G_f \times A_{base} \times \gamma_{base} = \mathbf{13.5 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma G_f \times A_{moist} \times \gamma_{mr}' = \mathbf{67.5 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{moist_v} = \mathbf{92.4 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{3.1 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{32.6 \text{ kN/m}}$$

Base soil

$$F_{exc_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b' \times (h_{pass} + h_{base})^2 / 2 = \mathbf{-5.1 \text{ kN/m}}$$

Total

$$F_{total_h} = F_{sur_h} + F_{moist_h} + F_{exc_h} = \mathbf{30.6 \text{ kN/m}}$$

Overturning moments on wall

Surcharge load

$$M_{sur_OT} = F_{sur_h} \times X_{sur_h} = \mathbf{4.3 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist_OT} = F_{moist_h} \times X_{moist_h} = \mathbf{30.3 \text{ kNm/m}}$$

Total

$$M_{total_OT} = M_{sur_OT} + M_{moist_OT} = \mathbf{34.6 \text{ kNm/m}}$$

Restoring moments on wall

Wall stem

$$M_{stem_R} = F_{stem} \times X_{stem} = \mathbf{3 \text{ kNm/m}}$$

Wall base

$$M_{base_R} = F_{base} \times X_{base} = \mathbf{12.2 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist_R} = F_{moist_v} \times X_{moist_v} = \mathbf{75.1 \text{ kNm/m}}$$

Base soil

$$M_{exc_R} = -F_{exc_h} \times X_{exc_h} = \mathbf{0.5 \text{ kNm/m}}$$

Total

$$M_{total_R} = M_{stem_R} + M_{base_R} + M_{moist_R} + M_{exc_R} = \mathbf{90.7 \text{ kNm/m}}$$

Check stability against overturning

Factor of safety

$$FoS_{ot} = M_{total_R} / M_{total_OT} = \mathbf{2.621}$$

PASS - Maximum restoring moment is greater than overturning moment

Bearing pressure check

Vertical forces on wall

Wall stem

$$F_{stem} = \gamma G \times A_{stem} \times \gamma_{stem} = \mathbf{15.4 \text{ kN/m}}$$

Wall base

$$F_{base} = \gamma G \times A_{base} \times \gamma_{base} = \mathbf{18.2 \text{ kN/m}}$$

Surcharge load

$$F_{sur_v} = \gamma_Q \times \text{Surcharge}_Q \times l_{heel} = \mathbf{5.3 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma G \times A_{moist} \times \gamma_{mr}' = \mathbf{91.2 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{sur_v} + F_{moist_v} = \mathbf{130.1 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{3.1 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{32.6 \text{ kN/m}}$$

Base soil

$$F_{pass_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b' \times (d_{cover} + h_{base})^2 / 2 = \mathbf{-5.1 \text{ kN/m}}$$

Total

$$F_{total_h} = \max(F_{sur_h} + F_{moist_h} + F_{pass_h} - F_{total_v} \times \tan(\delta_{bb,d}), 0 \text{ kN/m}) = \mathbf{0 \text{ kN/m}}$$

Moments on wall

Wall stem

$$M_{stem} = F_{stem} \times X_{stem} = \mathbf{4 \text{ kNm/m}}$$

Wall base

$$M_{base} = F_{base} \times X_{base} = \mathbf{16.4 \text{ kNm/m}}$$

Surcharge load

$$M_{sur} = F_{sur_v} \times X_{sur_v} - F_{sur_h} \times X_{sur_h} = \mathbf{1.5 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist} = F_{moist_v} \times X_{moist_v} - F_{moist_h} \times X_{moist_h} = \mathbf{71.1 \text{ kNm/m}}$$

Base soil

$$M_{pass} = -F_{pass_h} \times X_{pass_h} = \mathbf{0.5 \text{ kNm/m}}$$

Total

$$M_{total} = M_{stem} + M_{base} + M_{sur} + M_{moist} + M_{pass} = \mathbf{93.5 \text{ kNm/m}}$$

Check bearing pressure

Distance to reaction

$$\bar{X} = M_{total} / F_{total_v} = \mathbf{719 \text{ mm}}$$

Project				Job no.	
Calcs for				Start page no./Revision 5	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Eccentricity of reaction	$e = \bar{x} - l_{base} / 2 = -181 \text{ mm}$
Loaded length of base	$l_{load} = 2 \times \bar{x} = 1437 \text{ mm}$
Bearing pressure at toe	$q_{toe} = F_{total_v} / l_{load} = 90.5 \text{ kN/m}^2$
Bearing pressure at heel	$q_{heel} = 0 \text{ kN/m}^2$
Effective overburden pressure	$q = (t_{base} + d_{cover}) \times \gamma_{b'} = 5.4 \text{ kN/m}^2$
Design effective overburden pressure	$q' = q / \gamma_{\gamma} = 5.4 \text{ kN/m}^2$
Bearing resistance factors	$N_q = \text{Exp}(\pi \times \tan(\phi'_{b,d})) \times (\tan(45 \text{ deg} + \phi'_{b,d} / 2))^2 = 33.296$ $N_c = (N_q - 1) \times \cot(\phi'_{b,d}) = 46.124$ $N_{\gamma} = 2 \times (N_q - 1) \times \tan(\phi'_{b,d}) = 45.228$
Foundation shape factors	$s_q = 1$ $s_{\gamma} = 1$ $s_c = 1$
Load inclination factors	$H = F_{sur_h} + F_{moist_h} + F_{pass_h} = 30.6 \text{ kN/m}$ $V = F_{total_v} = 130.1 \text{ kN/m}$ $m = 2$ $i_q = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^m = 0.585$ $i_{\gamma} = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^{(m+1)} = 0.448$ $i_c = i_q - (1 - i_q) / (N_c \times \tan(\phi'_{b,d})) = 0.572$
Net ultimate bearing capacity	$n_f = c'_{b,d} \times N_c \times s_c \times i_c + q' \times N_q \times s_q \times i_q + 0.5 \times \gamma_{b'} \times l_{load} \times N_{\gamma} \times s_{\gamma} \times i_{\gamma} = 367.1 \text{ kN/m}^2$
Factor of safety	$FoS_{bp} = n_f / \max(q_{toe}, q_{heel}) = 4.056$ PASS - Allowable bearing pressure exceeds maximum applied bearing pressure

Design approach 1

Partial factors on actions - Table A.3 - Combination 2

Partial factor set	A2
Permanent unfavourable action	$\gamma_G = 1.000$
Permanent favourable action	$\gamma_{Gf} = 1.000$
Variable unfavourable action	$\gamma_Q = 1.300$
Variable favourable action	$\gamma_{Qf} = 0.000$

Partial factors for soil parameters – Table A.4 - Combination 2

Soil parameter set	M2
Angle of shearing resistance	$\gamma_{\phi'} = 1.25$
Effective cohesion	$\gamma_{c'} = 1.25$
Weight density	$\gamma_{\gamma} = 1.00$

Retained soil properties

Design moist density	$\gamma_{mr}' = \gamma_{mr} / \gamma_{\gamma} = 21 \text{ kN/m}^3$
Design saturated density	$\gamma_{sr}' = \gamma_{sr} / \gamma_{\gamma} = 23 \text{ kN/m}^3$
Design effective shear resistance angle	$\phi'_{r,d} = \text{atan}(\tan(\phi'_{r,k}) / \gamma_{\phi'}) = 29.3 \text{ deg}$
Design wall friction angle	$\delta_{r,d} = \text{atan}(\tan(\delta_{r,k}) / \gamma_{\phi'}) = 14.2 \text{ deg}$

Base soil properties

Design soil density	$\gamma_{b'} = \gamma_b / \gamma_{\gamma} = 18 \text{ kN/m}^3$
Design effective shear resistance angle	$\phi'_{b,d} = \text{atan}(\tan(\phi'_{b,k}) / \gamma_{\phi'}) = 29.3 \text{ deg}$
Design wall friction angle	$\delta_{b,d} = \text{atan}(\tan(\delta_{b,k}) / \gamma_{\phi'}) = 12.1 \text{ deg}$
Design base friction angle	$\delta_{bb,d} = \text{atan}(\tan(\delta_{bb,k}) / \gamma_{\phi'}) = 24.8 \text{ deg}$

Project				Job no.	
Calcs for				Start page no./Revision 6	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Design effective cohesion

$$c'_{b,d} = c'_{b,k} / \gamma_c = 0 \text{ kN/m}^2$$

Using Coulomb theory

Active pressure coefficient

$$K_A = \sin(\alpha + \phi'_{r,d})^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta_{r,d}) \times [1 + \sqrt{[\sin(\phi'_{r,d} + \delta_{r,d}) \times \sin(\phi'_{r,d} - \beta) / (\sin(\alpha - \delta_{r,d}) \times \sin(\alpha + \beta))]}])^2 = 0.411$$

Passive pressure coefficient

$$K_P = \sin(90 - \phi'_{b,d})^2 / (\sin(90 + \delta_{b,d}) \times [1 - \sqrt{[\sin(\phi'_{b,d} + \delta_{b,d}) \times \sin(\phi'_{b,d}) / (\sin(90 + \delta_{b,d}))]}])^2 = 4.303$$

Sliding check

Vertical forces on wall

Wall stem

$$F_{\text{stem}} = \gamma G_f \times A_{\text{stem}} \times \gamma_{\text{stem}} = 11.4 \text{ kN/m}$$

Wall base

$$F_{\text{base}} = \gamma G_f \times A_{\text{base}} \times \gamma_{\text{base}} = 13.5 \text{ kN/m}$$

Moist retained soil

$$F_{\text{moist}_v} = \gamma G_f \times A_{\text{moist}} \times \gamma_{\text{mr}} = 67.5 \text{ kN/m}$$

Total

$$F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} = 92.4 \text{ kN/m}$$

Horizontal forces on wall

Surcharge load

$$F_{\text{sur}_h} = K_A \times \cos(\delta_{r,d}) \times \gamma Q \times \text{Surcharge}_Q \times h_{\text{eff}} = 3.6 \text{ kN/m}$$

Moist retained soil

$$F_{\text{moist}_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{\text{mr}} \times h_{\text{eff}}^2 / 2 = 32.6 \text{ kN/m}$$

Total

$$F_{\text{total}_h} = F_{\text{sur}_h} + F_{\text{moist}_h} = 36.2 \text{ kN/m}$$

Check stability against sliding

Base soil resistance

$$F_{\text{exc}_h} = \gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b \times (h_{\text{pass}} + h_{\text{base}})^2 / 2 = 3.4 \text{ kN/m}$$

Base friction

$$F_{\text{friction}} = F_{\text{total}_v} \times \tan(\delta_{bb,d}) = 42.7 \text{ kN/m}$$

Resistance to sliding

$$F_{\text{rest}} = F_{\text{exc}_h} + F_{\text{friction}} = 46.1 \text{ kN/m}$$

Factor of safety

$$F_{\text{OSsl}} = F_{\text{rest}} / F_{\text{total}_h} = 1.274$$

PASS - Resistance to sliding is greater than sliding force

Overtipping check

Vertical forces on wall

Wall stem

$$F_{\text{stem}} = \gamma G_f \times A_{\text{stem}} \times \gamma_{\text{stem}} = 11.4 \text{ kN/m}$$

Wall base

$$F_{\text{base}} = \gamma G_f \times A_{\text{base}} \times \gamma_{\text{base}} = 13.5 \text{ kN/m}$$

Moist retained soil

$$F_{\text{moist}_v} = \gamma G_f \times A_{\text{moist}} \times \gamma_{\text{mr}} = 67.5 \text{ kN/m}$$

Total

$$F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} = 92.4 \text{ kN/m}$$

Horizontal forces on wall

Surcharge load

$$F_{\text{sur}_h} = K_A \times \cos(\delta_{r,d}) \times \gamma Q \times \text{Surcharge}_Q \times h_{\text{eff}} = 3.6 \text{ kN/m}$$

Moist retained soil

$$F_{\text{moist}_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{\text{mr}} \times h_{\text{eff}}^2 / 2 = 32.6 \text{ kN/m}$$

Base soil

$$F_{\text{exc}_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b \times (h_{\text{pass}} + h_{\text{base}})^2 / 2 = -3.4 \text{ kN/m}$$

Total

$$F_{\text{total}_h} = F_{\text{sur}_h} + F_{\text{moist}_h} + F_{\text{exc}_h} = 32.8 \text{ kN/m}$$

Overtipping moments on wall

Surcharge load

$$M_{\text{sur}_OT} = F_{\text{sur}_h} \times X_{\text{sur}_h} = 5 \text{ kNm/m}$$

Moist retained soil

$$M_{\text{moist}_OT} = F_{\text{moist}_h} \times X_{\text{moist}_h} = 30.3 \text{ kNm/m}$$

Total

$$M_{\text{total}_OT} = M_{\text{sur}_OT} + M_{\text{moist}_OT} = 35.3 \text{ kNm/m}$$

Restoring moments on wall

Wall stem

$$M_{\text{stem}_R} = F_{\text{stem}} \times X_{\text{stem}} = 3 \text{ kNm/m}$$

Wall base

$$M_{\text{base}_R} = F_{\text{base}} \times X_{\text{base}} = 12.2 \text{ kNm/m}$$

Moist retained soil

$$M_{\text{moist}_R} = F_{\text{moist}_v} \times X_{\text{moist}_v} = 75.1 \text{ kNm/m}$$

Base soil

$$M_{\text{exc}_R} = -F_{\text{exc}_h} \times X_{\text{exc}_h} = 0.3 \text{ kNm/m}$$

Total

$$M_{\text{total}_R} = M_{\text{stem}_R} + M_{\text{base}_R} + M_{\text{moist}_R} + M_{\text{exc}_R} = 90.6 \text{ kNm/m}$$

Project				Job no.	
Calcs for				Start page no./Revision 7	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Check stability against overturning

Factor of safety

$$FoS_{ot} = M_{total_R} / M_{total_OT} = \mathbf{2.566}$$

PASS - Maximum restoring moment is greater than overturning moment

Bearing pressure check

Vertical forces on wall

Wall stem

$$F_{stem} = \gamma_G \times A_{stem} \times \gamma_{stem} = \mathbf{11.4 \text{ kN/m}}$$

Wall base

$$F_{base} = \gamma_G \times A_{base} \times \gamma_{base} = \mathbf{13.5 \text{ kN/m}}$$

Surcharge load

$$F_{sur_v} = \gamma_Q \times \text{Surcharge}_Q \times l_{heel} = \mathbf{4.6 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma_G \times A_{moist} \times \gamma_{mr}' = \mathbf{67.5 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{sur_v} + F_{moist_v} = \mathbf{97 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{3.6 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma_G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{32.6 \text{ kN/m}}$$

Base soil

$$F_{pass_h} = -\gamma_G \times K_P \times \cos(\delta_{b,d}) \times \gamma_{b'} \times (d_{cover} + h_{base})^2 / 2 = \mathbf{-3.4 \text{ kN/m}}$$

Total

$$F_{total_h} = \max(F_{sur_h} + F_{moist_h} + F_{pass_h} - F_{total_v} \times \tan(\delta_{bb,d}), 0 \text{ kN/m}) = \mathbf{0 \text{ kN/m}}$$

Moments on wall

Wall stem

$$M_{stem} = F_{stem} \times X_{stem} = \mathbf{3 \text{ kNm/m}}$$

Wall base

$$M_{base} = F_{base} \times X_{base} = \mathbf{12.2 \text{ kNm/m}}$$

Surcharge load

$$M_{sur} = F_{sur_v} \times X_{sur_v} - F_{sur_h} \times X_{sur_h} = \mathbf{0 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist} = F_{moist_v} \times X_{moist_v} - F_{moist_h} \times X_{moist_h} = \mathbf{44.8 \text{ kNm/m}}$$

Base soil

$$M_{pass} = -F_{pass_h} \times X_{pass_h} = \mathbf{0.3 \text{ kNm/m}}$$

Total

$$M_{total} = M_{stem} + M_{base} + M_{sur} + M_{moist} + M_{pass} = \mathbf{60.3 \text{ kNm/m}}$$

Check bearing pressure

Distance to reaction

$$\bar{x} = M_{total} / F_{total_v} = \mathbf{621 \text{ mm}}$$

Eccentricity of reaction

$$e = \bar{x} - l_{base} / 2 = \mathbf{-279 \text{ mm}}$$

Loaded length of base

$$l_{load} = 2 \times \bar{x} = \mathbf{1243 \text{ mm}}$$

Bearing pressure at toe

$$q_{toe} = F_{total_v} / l_{load} = \mathbf{78.1 \text{ kN/m}^2}$$

Bearing pressure at heel

$$q_{heel} = \mathbf{0 \text{ kN/m}^2}$$

Effective overburden pressure

$$q = (t_{base} + d_{cover}) \times \gamma_{b'} = \mathbf{5.4 \text{ kN/m}^2}$$

Design effective overburden pressure

$$q' = q / \gamma_{\gamma} = \mathbf{5.4 \text{ kN/m}^2}$$

Bearing resistance factors

$$N_q = \text{Exp}(\pi \times \tan(\phi'_{b,d})) \times (\tan(45 \text{ deg} + \phi'_{b,d} / 2))^2 = \mathbf{16.921}$$

$$N_c = (N_q - 1) \times \cot(\phi'_{b,d}) = \mathbf{28.422}$$

$$N_{\gamma} = 2 \times (N_q - 1) \times \tan(\phi'_{b,d}) = \mathbf{17.837}$$

Foundation shape factors

$$s_q = 1$$

$$s_{\gamma} = 1$$

$$s_c = 1$$

Load inclination factors

$$H = F_{sur_h} + F_{moist_h} + F_{pass_h} = \mathbf{32.8 \text{ kN/m}}$$

$$V = F_{total_v} = \mathbf{97 \text{ kN/m}}$$

$$m = 2$$

$$i_q = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^m = \mathbf{0.439}$$

$$i_{\gamma} = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^{(m+1)} = \mathbf{0.291}$$

$$i_c = i_q - (1 - i_q) / (N_c \times \tan(\phi'_{b,d})) = \mathbf{0.404}$$

Net ultimate bearing capacity

Project				Job no.	
Calcs for				Start page no./Revision 8	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

$$n_f = c'_{b,d} \times N_c \times s_c \times i_c + q' \times N_q \times s_q \times i_q + 0.5 \times \gamma_b' \times l_{load} \times N_\gamma \times s_\gamma \times i_\gamma = \mathbf{98.1 \text{ kN/m}^2}$$

Factor of safety

$$FoS_{bp} = n_f / \max(q_{toe}, q_{heel}) = \mathbf{1.256}$$

PASS - Allowable bearing pressure exceeds maximum applied bearing pressure

RETAINING WALL DESIGN

In accordance with EN1992-1-1:2004 incorporating Corrigendum dated January 2008 and the UK National Annex incorporating National Amendment No.1

Tedds calculation version 2.9.22

Concrete details - Table 3.1 - Strength and deformation characteristics for concrete

Concrete strength class	C30/37
Characteristic compressive cylinder strength	$f_{ck} = \mathbf{30 \text{ N/mm}^2}$
Characteristic compressive cube strength	$f_{ck,cube} = \mathbf{37 \text{ N/mm}^2}$
Mean value of compressive cylinder strength	$f_{cm} = f_{ck} + 8 \text{ N/mm}^2 = \mathbf{38 \text{ N/mm}^2}$
Mean value of axial tensile strength	$f_{ctm} = 0.3 \text{ N/mm}^2 \times (f_{ck} / 1 \text{ N/mm}^2)^{2/3} = \mathbf{2.9 \text{ N/mm}^2}$
5% fractile of axial tensile strength	$f_{ctk,0.05} = 0.7 \times f_{ctm} = \mathbf{2.0 \text{ N/mm}^2}$
Secant modulus of elasticity of concrete	$E_{cm} = 22 \text{ kN/mm}^2 \times (f_{cm} / 10 \text{ N/mm}^2)^{0.3} = \mathbf{32837 \text{ N/mm}^2}$
Partial factor for concrete - Table 2.1N	$\gamma_C = \mathbf{1.50}$
Compressive strength coefficient - cl.3.1.6(1)	$\alpha_{cc} = \mathbf{0.85}$
Design compressive concrete strength - exp.3.15	$f_{cd} = \alpha_{cc} \times f_{ck} / \gamma_C = \mathbf{17.0 \text{ N/mm}^2}$
Maximum aggregate size	$h_{agg} = \mathbf{20 \text{ mm}}$
Ultimate strain - Table 3.1	$\epsilon_{cu2} = \mathbf{0.0035}$
Shortening strain - Table 3.1	$\epsilon_{cu3} = \mathbf{0.0035}$
Effective compression zone height factor	$\lambda = \mathbf{0.80}$
Effective strength factor	$\eta = \mathbf{1.00}$
Bending coefficient k_1	$K_1 = \mathbf{0.40}$
Bending coefficient k_2	$K_2 = 1.00 \times (0.6 + 0.0014/\epsilon_{cu2}) = \mathbf{1.00}$
Bending coefficient k_3	$K_3 = \mathbf{0.40}$
Bending coefficient k_4	$K_4 = 1.00 \times (0.6 + 0.0014/\epsilon_{cu2}) = \mathbf{1.00}$







Reinforcement details

Characteristic yield strength of reinforcement	$f_{yk} = \mathbf{500 \text{ N/mm}^2}$
Modulus of elasticity of reinforcement	$E_s = \mathbf{200000 \text{ N/mm}^2}$
Partial factor for reinforcing steel - Table 2.1N	$\gamma_S = \mathbf{1.15}$
Design yield strength of reinforcement	$f_{yd} = f_{yk} / \gamma_S = \mathbf{435 \text{ N/mm}^2}$

Cover to reinforcement

Front face of stem	$c_{sf} = \mathbf{40 \text{ mm}}$
Rear face of stem	$c_{sr} = \mathbf{50 \text{ mm}}$
Top face of base	$c_{bt} = \mathbf{50 \text{ mm}}$
Bottom face of base	$c_{bb} = \mathbf{75 \text{ mm}}$

Project				Job no.	
Calcs for				Start page no./Revision 9	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date



Check stem design at base of stem

Depth of section

$h = 225 \text{ mm}$

Rectangular section in flexure - Section 6.1

Design bending moment combination 2

$M = 14.3 \text{ kNm/m}$

Depth to tension reinforcement

$d = h - C_{sr} - \phi_{sr} / 2 = 170 \text{ mm}$

$K = M / (d^2 \times f_{ck}) = 0.016$

$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$

$K' = 0.207$

$K' > K$ - No compression reinforcement is required

Lever arm

$z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 161 \text{ mm}$

Depth of neutral axis

$x = 2.5 \times (d - z) = 21 \text{ mm}$

Area of tension reinforcement required

$A_{s,req} = M / (f_{yd} \times z) = 203 \text{ mm}^2/\text{m}$

Tension reinforcement provided

10 dia.bars @ 200 c/c



Project				Job no.	
Calcs for				Start page no./Revision 10	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Area of tension reinforcement provided

$$A_{sr,prov} = \pi \times \phi_{sr}^2 / (4 \times s_{sr}) = \mathbf{393 \text{ mm}^2/m}$$

Minimum area of reinforcement - exp.9.1N

$$A_{sr,min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = \mathbf{256 \text{ mm}^2/m}$$

Maximum area of reinforcement - cl.9.2.1.1(3)

$$A_{sr,max} = 0.04 \times h = \mathbf{9000 \text{ mm}^2/m}$$

$$\max(A_{sr,req}, A_{sr,min}) / A_{sr,prov} = \mathbf{0.652}$$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Deflection control - Section 7.4

Reference reinforcement ratio

$$\rho_0 = \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} / 1000 = \mathbf{0.005}$$

Required tension reinforcement ratio

$$\rho = A_{sr,req} / d = \mathbf{0.001}$$

Required compression reinforcement ratio

$$\rho' = A_{sr,2,req} / d_2 = \mathbf{0.000}$$

Structural system factor - Table 7.4N

$$K_b = \mathbf{0.4}$$

Reinforcement factor - exp.7.17

$$K_s = \min(500 \text{ N/mm}^2 / (f_{yk} \times A_{sr,req} / A_{sr,prov}), 1.5) = \mathbf{1.5}$$

Limiting span to depth ratio - exp.7.16.a

$$\min(K_s \times K_b \times [11 + 1.5 \times \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} \times \rho_0 / \rho + 3.2 \times \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} \times (\rho_0 / \rho - 1)^{3/2}], 40 \times K_b) = \mathbf{16}$$

Actual span to depth ratio

$$h_{stem} / d = \mathbf{11.9}$$

PASS - Span to depth ratio is less than deflection control limit

Crack control - Section 7.3

Limiting crack width

$$w_{max} = \mathbf{0.3 \text{ mm}}$$

Variable load factor - EN1990 – Table A1.1

$$\psi_2 = \mathbf{0.6}$$

Serviceability bending moment

$$M_{sls} = \mathbf{9.5 \text{ kNm/m}}$$

Tensile stress in reinforcement

$$\sigma_s = M_{sls} / (A_{sr,prov} \times z) = \mathbf{150 \text{ N/mm}^2}$$

Load duration

Long term

Load duration factor

$$k_t = \mathbf{0.4}$$

Effective area of concrete in tension

$$A_{c,eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$$

$$A_{c,eff} = \mathbf{67917 \text{ mm}^2/m}$$

Mean value of concrete tensile strength

$$f_{ct,eff} = f_{ctm} = \mathbf{2.9 \text{ N/mm}^2}$$

Reinforcement ratio

$$\rho_{p,eff} = A_{sr,prov} / A_{c,eff} = \mathbf{0.006}$$

Modular ratio

$$\alpha_e = E_s / E_{cm} = \mathbf{6.091}$$

Bond property coefficient

$$k_1 = \mathbf{0.8}$$

Strain distribution coefficient

$$k_2 = \mathbf{0.5}$$

$$k_3 = \mathbf{3.4}$$

$$k_4 = \mathbf{0.425}$$

Maximum crack spacing - exp.7.11

$$s_{r,max} = k_3 \times C_{sr} + k_1 \times k_2 \times k_4 \times \phi_{sr} / \rho_{p,eff} = \mathbf{464 \text{ mm}}$$

Maximum crack width - exp.7.8

$$w_k = s_{r,max} \times \max(\sigma_s - k_t \times (f_{ct,eff} / \rho_{p,eff}) \times (1 + \alpha_e \times \rho_{p,eff}), 0.6 \times \sigma_s) / E_s$$

$$w_k = \mathbf{0.209 \text{ mm}}$$

$$w_k / w_{max} = \mathbf{0.696}$$

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$$V = \mathbf{19.8 \text{ kN/m}}$$

$$C_{Rd,c} = 0.18 / \gamma_c = \mathbf{0.120}$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = \mathbf{2.000}$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{sr,prov} / d, 0.02) = \mathbf{0.002}$$

$$v_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = \mathbf{0.542 \text{ N/mm}^2}$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, v_{min}) \times d$$

$$V_{Rd,c} = \mathbf{92.2 \text{ kN/m}}$$

$$V / V_{Rd,c} = \mathbf{0.215}$$



Project				Job no.	
Calcs for				Start page no./Revision 11	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

PASS - Design shear resistance exceeds design shear force

Horizontal reinforcement parallel to face of stem - Section 9.6

Minimum area of reinforcement – cl.9.6.3(1) $A_{sx.req} = \max(0.25 \times A_{sr.prov}, 0.001 \times t_{stem}) = 225 \text{ mm}^2/\text{m}$

Maximum spacing of reinforcement – cl.9.6.3(2) $s_{sx.max} = 400 \text{ mm}$

Transverse reinforcement provided 10 dia.bars @ 200 c/c

Area of transverse reinforcement provided $A_{sx.prov} = \pi \times \phi_{sx}^2 / (4 \times s_{sx}) = 393 \text{ mm}^2/\text{m}$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Check base design at toe

Depth of section $h = 300 \text{ mm}$

Rectangular section in flexure - Section 6.1

Design bending moment combination 1 $M = 2.1 \text{ kNm/m}$

Depth to tension reinforcement $d = h - C_{bb} - \phi_{bb} / 2 = 219 \text{ mm}$

$K = M / (d^2 \times f_{ck}) = 0.001$

$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$

$K' = 0.207$

$K' > K$ - No compression reinforcement is required

Lever arm $z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 208 \text{ mm}$

Depth of neutral axis $x = 2.5 \times (d - z) = 27 \text{ mm}$

Area of tension reinforcement required $A_{bb.req} = M / (f_{yd} \times z) = 23 \text{ mm}^2/\text{m}$

Tension reinforcement provided 12 dia.bars @ 200 c/c

Area of tension reinforcement provided $A_{bb.prov} = \pi \times \phi_{bb}^2 / (4 \times S_{bb}) = 565 \text{ mm}^2/\text{m}$

Minimum area of reinforcement - exp.9.1N $A_{bb.min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = 330 \text{ mm}^2/\text{m}$

Maximum area of reinforcement - cl.9.2.1.1(3) $A_{bb.max} = 0.04 \times h = 12000 \text{ mm}^2/\text{m}$

$\max(A_{bb.req}, A_{bb.min}) / A_{bb.prov} = 0.583$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Crack control - Section 7.3

Limiting crack width $w_{max} = 0.3 \text{ mm}$

Variable load factor - EN1990 – Table A1.1 $\psi_2 = 0.6$

Serviceability bending moment $M_{sls} = 1.5 \text{ kNm/m}$

Tensile stress in reinforcement $\sigma_s = M_{sls} / (A_{bb.prov} \times z) = 12.8 \text{ N/mm}^2$

Load duration Long term

Load duration factor $k_t = 0.4$

Effective area of concrete in tension $A_{c.eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$

$A_{c.eff} = 90875 \text{ mm}^2/\text{m}$

Mean value of concrete tensile strength $f_{ct.eff} = f_{ctm} = 2.9 \text{ N/mm}^2$

Reinforcement ratio $\rho_{p.eff} = A_{bb.prov} / A_{c.eff} = 0.006$

Modular ratio $\alpha_e = E_s / E_{cm} = 6.091$

Bond property coefficient $k_1 = 0.8$

Strain distribution coefficient $k_2 = 0.5$

$k_3 = 3.4$

$k_4 = 0.425$

Maximum crack spacing - exp.7.11 $s_{r.max} = k_3 \times C_{bb} + k_1 \times k_2 \times k_4 \times \phi_{bb} / \rho_{p.eff} = 583 \text{ mm}$

Maximum crack width - exp.7.8 $w_k = s_{r.max} \times \max(\sigma_s - k_t \times (f_{ct.eff} / \rho_{p.eff}) \times (1 + \alpha_e \times \rho_{p.eff}), 0.6 \times \sigma_s) / E_s$

$w_k = 0.022 \text{ mm}$

$w_k / w_{max} = 0.074$



Project				Job no.	
Calcs for				Start page no./Revision 12	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$$V = 16.8 \text{ kN/m}$$

$$C_{Rd,c} = 0.18 / \gamma_c = 0.120$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = 1.956$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{bb,prov} / d, 0.02) = 0.003$$

$$V_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = 0.524 \text{ N/mm}^2$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, V_{min}) \times d$$

$$V_{Rd,c} = 114.8 \text{ kN/m}$$

$$V / V_{Rd,c} = 0.146$$

PASS - Design shear resistance exceeds design shear force

Check base design at heel

Depth of section

$$h = 300 \text{ mm}$$

Rectangular section in flexure - Section 6.1

Design bending moment combination 2

$$M = 12.8 \text{ kNm/m}$$

Depth to tension reinforcement

$$d = h - c_{bt} - \phi_{bt} / 2 = 244 \text{ mm}$$

$$K = M / (d^2 \times f_{ck}) = 0.007$$

$$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$$

$$K' = 0.207$$

$K' > K$ - No compression reinforcement is required

Lever arm

$$z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 232 \text{ mm}$$

Depth of neutral axis

$$x = 2.5 \times (d - z) = 31 \text{ mm}$$

Area of tension reinforcement required

$$A_{bt,req} = M / (f_{yd} \times z) = 127 \text{ mm}^2/\text{m}$$

Tension reinforcement provided

$$12 \text{ dia. bars @ } 200 \text{ c/c}$$

Area of tension reinforcement provided

$$A_{bt,prov} = \pi \times \phi_{bt}^2 / (4 \times s_{bt}) = 565 \text{ mm}^2/\text{m}$$

Minimum area of reinforcement - exp.9.1N

$$A_{bt,min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = 368 \text{ mm}^2/\text{m}$$

Maximum area of reinforcement - cl.9.2.1.1(3)

$$A_{bt,max} = 0.04 \times h = 12000 \text{ mm}^2/\text{m}$$

$$\max(A_{bt,req}, A_{bt,min}) / A_{bt,prov} = 0.65$$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Crack control - Section 7.3

Limiting crack width

$$w_{max} = 0.3 \text{ mm}$$

Variable load factor - EN1990 – Table A1.1

$$\psi_2 = 0.6$$

Serviceability bending moment

$$M_{sis} = 7.8 \text{ kNm/m}$$

Tensile stress in reinforcement

$$\sigma_s = M_{sis} / (A_{bt,prov} \times z) = 59.7 \text{ N/mm}^2$$

Load duration

Long term

Load duration factor

$$k_t = 0.4$$

Effective area of concrete in tension

$$A_{c,eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$$

$$A_{c,eff} = 89833 \text{ mm}^2/\text{m}$$

Mean value of concrete tensile strength

$$f_{ct,eff} = f_{ctm} = 2.9 \text{ N/mm}^2$$

Reinforcement ratio

$$\rho_{p,eff} = A_{bt,prov} / A_{c,eff} = 0.006$$

Modular ratio

$$\alpha_e = E_s / E_{cm} = 6.091$$

Bond property coefficient

$$k_1 = 0.8$$

Strain distribution coefficient

$$k_2 = 0.5$$

$$k_3 = 3.4$$

$$k_4 = 0.425$$

Project				Job no.	
Calcs for				Start page no./Revision 13	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Maximum crack spacing - exp.7.11

$$s_{r,max} = k_3 \times C_{bt} + k_1 \times k_2 \times k_4 \times \phi_{bt} / \rho_{p,eff} = \mathbf{494 \text{ mm}}$$

Maximum crack width - exp.7.8

$$w_k = s_{r,max} \times \max(\sigma_s - k_t \times (f_{ct,eff} / \rho_{p,eff}) \times (1 + \alpha_e \times \rho_{p,eff}), 0.6 \times \sigma_s) / E_s$$

$$w_k = \mathbf{0.089 \text{ mm}}$$

$$w_k / w_{max} = \mathbf{0.295}$$

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$$V = \mathbf{11.5 \text{ kN/m}}$$

$$C_{Rd,c} = 0.18 / \gamma_C = \mathbf{0.120}$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = \mathbf{1.905}$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{bt,prov} / d, 0.02) = \mathbf{0.002}$$

$$v_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = \mathbf{0.504 \text{ N/mm}^2}$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, v_{min}) \times d$$

$$V_{Rd,c} = \mathbf{123 \text{ kN/m}}$$

$$V / V_{Rd,c} = \mathbf{0.094}$$

PASS - Design shear resistance exceeds design shear force

Secondary transverse reinforcement to base - Section 9.3

Minimum area of reinforcement – cl.9.3.1.1(2)

$$A_{bx,req} = 0.2 \times A_{bb,prov} = \mathbf{113 \text{ mm}^2/\text{m}}$$

Maximum spacing of reinforcement – cl.9.3.1.1(3)

$$s_{bx,max} = \mathbf{450 \text{ mm}}$$


Transverse reinforcement provided

$$\mathbf{10 \text{ dia. bars @ } 200 \text{ c/c}}$$

Area of transverse reinforcement provided

$$A_{bx,prov} = \pi \times \phi_{bx}^2 / (4 \times s_{bx}) = \mathbf{393 \text{ mm}^2/\text{m}}$$

PASS - Area of reinforcement provided is greater than area of reinforcement required






Tekla® Tedds

Shear Design
7 Ash Tree Court
Cardiff Gate Business Park
CF23 8RW

Project				Job no.	
Calcs for				Start page no./Revision 14	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date



Project				Job no.	
Calcs for				Start page no./Revision 1	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

RETAINING WALL ANALYSIS

In accordance with EN1997-1:2004 incorporating Corrigendum dated February 2009 and the UK National Annex incorporating Corrigendum No.1

Tedds calculation version 2.9.22

Analysis summary

Design summary

Overall design utilisation 0.775

Overall design status Pass

Description	Unit	Capacity	Applied	F o S	Result
Sliding stability	kN/m	41	31.8	1.290	PASS
Overturning stability	kNm/m	75.6	29.1	2.599	PASS
Bearing pressure	kN/m ²	98	72.1	1.358	PASS

Design summary

Description	Unit	Provided	Required	Utilisation	Result
Shear resistance	kN/m	114.8	14.7	0.128	PASS
Base top face - Flexural reinforcement	mm ² /m	565.5	367.5	0.650	PASS
Base bottom face - Flexural reinforcement	mm ² /m	565.5	329.8	0.583	PASS
Base - Shear resistance	kN/m	114.8	14.7	0.128	PASS
Min. transverse stem reinf.	mm ² /m	392.7	225.0	0.573	PASS
Min. transverse base reinf.	mm ² /m	392.7	113.1	0.288	PASS

Retaining wall details

Stem type	Cantilever
Stem height	$h_{\text{stem}} = 1875$ mm
Stem thickness	$t_{\text{stem}} = 225$ mm
Angle to rear face of stem	$\alpha = 90$ deg
Stem density	$\gamma_{\text{stem}} = 25$ kN/m ³
Toe length	$l_{\text{toe}} = 150$ mm
Heel length	$l_{\text{heel}} = 1325$ mm
Base thickness	$t_{\text{base}} = 300$ mm
Base density	$\gamma_{\text{base}} = 25$ kN/m ³
Height of retained soil	$h_{\text{ret}} = 1875$ mm
Angle of soil surface	$\beta = 18$ deg
Depth of cover	$d_{\text{cover}} = 0$ mm

Retained soil properties

Soil type	Medium dense well graded sand
Moist density	$\gamma_{\text{mr}} = 21$ kN/m ³
Saturated density	$\gamma_{\text{sr}} = 23$ kN/m ³
Characteristic effective shear resistance angle	$\phi'_{r,k} = 35$ deg
Characteristic wall friction angle	$\delta_{r,k} = 17.5$ deg

Base soil properties


Soil type	Medium dense well graded sand
Soil density	$\gamma_b = 18$ kN/m ³
Characteristic cohesion	$c'_{b,k} = 0$ kN/m ²
Characteristic effective shear resistance angle	$\phi'_{b,k} = 35$ deg
Characteristic wall friction angle	$\delta_{b,k} = 15$ deg
Characteristic base friction angle	$\delta_{bb,k} = 30$ deg

Project				Job no.	
Calcs for				Start page no./Revision 2	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Loading details

Variable surcharge load

Surcharge₀ = 2.5 kN/m²



General arrangement - sketch pressures relate to bearing check

Calculate retaining wall geometry

Base length

$$l_{base} = l_{toe} + t_{stem} + l_{heel} = 1700 \text{ mm}$$

Moist soil height

$$h_{moist} = h_{soil} = 1875 \text{ mm}$$

Length of surcharge load

$$l_{sur} = l_{heel} = 1325 \text{ mm}$$

- Distance to vertical component

$$x_{sur_v} = l_{base} - l_{heel} / 2 = 1038 \text{ mm}$$

Effective height of wall

$$h_{eff} = h_{base} + d_{cover} + h_{ret} + l_{sur} \times \tan(\beta) = 2606 \text{ mm}$$

- Distance to horizontal component

$$x_{sur_h} = h_{eff} / 2 = 1303 \text{ mm}$$

Area of wall stem

$$A_{stem} = h_{stem} \times t_{stem} = 0.422 \text{ m}^2$$

- Distance to vertical component

$$x_{stem} = l_{toe} + t_{stem} / 2 = 263 \text{ mm}$$

Area of wall base

$$A_{base} = l_{base} \times t_{base} = 0.51 \text{ m}^2$$

- Distance to vertical component

$$x_{base} = l_{base} / 2 = 850 \text{ mm}$$

Area of moist soil

$$A_{moist} = h_{moist} \times l_{heel} + \tan(\beta) \times l_{heel}^2 / 2 = 2.77 \text{ m}^2$$

- Distance to vertical component

$$x_{moist_v} = l_{base} - (h_{moist} \times l_{heel}^2 / 2 + \tan(\beta) \times l_{heel}^3 / 6) / A_{moist} = 1060 \text{ mm}$$

- Distance to horizontal component

$$x_{moist_h} = h_{eff} / 3 = 869 \text{ mm}$$

Design approach 1

Partial factors on actions - Table A.3 - Combination 1

Partial factor set

A1

Permanent unfavourable action

$\gamma_G = 1.350$

Permanent favourable action

$\gamma_{Gf} = 1.000$

Project				Job no.	
Calcs for				Start page no./Revision 3	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Variable unfavourable action $\gamma_Q = 1.500$
Variable favourable action $\gamma_{Qf} = 0.000$

Partial factors for soil parameters – Table A.4 - Combination 1

Soil parameter set **M1**
Angle of shearing resistance $\gamma_{\phi'} = 1.00$
Effective cohesion $\gamma_{c'} = 1.00$
Weight density $\gamma_{\gamma} = 1.00$

Retained soil properties

Design moist density $\gamma_{mr'} = \gamma_{mr} / \gamma_{\gamma} = 21 \text{ kN/m}^3$
Design saturated density $\gamma_{sr'} = \gamma_{sr} / \gamma_{\gamma} = 23 \text{ kN/m}^3$
Design effective shear resistance angle $\phi'_{r,d} = \text{atan}(\tan(\phi'_{r,k}) / \gamma_{\phi'}) = 35 \text{ deg}$
Design wall friction angle $\delta_{r,d} = \text{atan}(\tan(\delta_{r,k}) / \gamma_{\phi'}) = 17.5 \text{ deg}$

Base soil properties

Design soil density $\gamma_{b'} = \gamma_b / \gamma_{\gamma} = 18 \text{ kN/m}^3$
Design effective shear resistance angle $\phi'_{b,d} = \text{atan}(\tan(\phi'_{b,k}) / \gamma_{\phi'}) = 35 \text{ deg}$
Design wall friction angle $\delta_{b,d} = \text{atan}(\tan(\delta_{b,k}) / \gamma_{\phi'}) = 15 \text{ deg}$
Design base friction angle $\delta_{bb,d} = \text{atan}(\tan(\delta_{bb,k}) / \gamma_{\phi'}) = 30 \text{ deg}$
Design effective cohesion $c'_{b,d} = c'_{b,k} / \gamma_{c'} = 0 \text{ kN/m}^2$

Using Coulomb theory

Active pressure coefficient $K_A = \sin(\alpha + \phi'_{r,d})^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta_{r,d}) \times [1 + \sqrt{[\sin(\phi'_{r,d} + \delta_{r,d}) \times \sin(\phi'_{r,d} - \beta) / (\sin(\alpha - \delta_{r,d}) \times \sin(\alpha + \beta))]}])^2 = 0.310$
Passive pressure coefficient $K_P = \sin(90 - \phi'_{b,d})^2 / (\sin(90 + \delta_{b,d}) \times [1 - \sqrt{[\sin(\phi'_{b,d} + \delta_{b,d}) \times \sin(\phi'_{b,d}) / (\sin(90 + \delta_{b,d}))]}])^2 = 6.555$

Sliding check

Vertical forces on wall

Wall stem $F_{\text{stem}} = \gamma_{Gf} \times A_{\text{stem}} \times \gamma_{\text{stem}} = 10.5 \text{ kN/m}$
Wall base $F_{\text{base}} = \gamma_{Gf} \times A_{\text{base}} \times \gamma_{\text{base}} = 12.8 \text{ kN/m}$
Moist retained soil $F_{\text{moist}_v} = \gamma_{Gf} \times A_{\text{moist}} \times \gamma_{mr'} = 58.2 \text{ kN/m}$
Total $F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} = 81.5 \text{ kN/m}$

Horizontal forces on wall

Surcharge load $F_{\text{sur}_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{\text{eff}} = 2.9 \text{ kN/m}$
Moist retained soil $F_{\text{moist}_h} = \gamma_G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr'} \times h_{\text{eff}}^2 / 2 = 28.5 \text{ kN/m}$
Total $F_{\text{total}_h} = F_{\text{sur}_h} + F_{\text{moist}_h} = 31.4 \text{ kN/m}$

Check stability against sliding

Base soil resistance $F_{\text{exc}_h} = \gamma_{Gf} \times K_P \times \cos(\delta_{b,d}) \times \gamma_{b'} \times (h_{\text{pass}} + h_{\text{base}})^2 / 2 = 5.1 \text{ kN/m}$
Base friction $F_{\text{friction}} = F_{\text{total}_v} \times \tan(\delta_{bb,d}) = 47 \text{ kN/m}$
Resistance to sliding $F_{\text{rest}} = F_{\text{exc}_h} + F_{\text{friction}} = 52.2 \text{ kN/m}$
Factor of safety $FoS_{\text{sl}} = F_{\text{rest}} / F_{\text{total}_h} = 1.662$

PASS - Resistance to sliding is greater than sliding force

Overtipping check

Vertical forces on wall

Wall stem $F_{\text{stem}} = \gamma_{Gf} \times A_{\text{stem}} \times \gamma_{\text{stem}} = 10.5 \text{ kN/m}$

Project				Job no.	
Calcs for				Start page no./Revision 4	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Wall base

$$F_{base} = \gamma G_f \times A_{base} \times \gamma_{base} = \mathbf{12.8 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma G_f \times A_{moist} \times \gamma_{mr}' = \mathbf{58.2 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{moist_v} = \mathbf{81.5 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{2.9 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{28.5 \text{ kN/m}}$$

Base soil

$$F_{exc_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b' \times (h_{pass} + h_{base})^2 / 2 = \mathbf{-5.1 \text{ kN/m}}$$

Total

$$F_{total_h} = F_{sur_h} + F_{moist_h} + F_{exc_h} = \mathbf{26.2 \text{ kN/m}}$$

Overturning moments on wall

Surcharge load

$$M_{sur_OT} = F_{sur_h} \times X_{sur_h} = \mathbf{3.8 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist_OT} = F_{moist_h} \times X_{moist_h} = \mathbf{24.7 \text{ kNm/m}}$$

Total

$$M_{total_OT} = M_{sur_OT} + M_{moist_OT} = \mathbf{28.5 \text{ kNm/m}}$$

Restoring moments on wall

Wall stem

$$M_{stem_R} = F_{stem} \times X_{stem} = \mathbf{2.8 \text{ kNm/m}}$$

Wall base

$$M_{base_R} = F_{base} \times X_{base} = \mathbf{10.8 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist_R} = F_{moist_v} \times X_{moist_v} = \mathbf{61.7 \text{ kNm/m}}$$

Base soil

$$M_{exc_R} = -F_{exc_h} \times X_{exc_h} = \mathbf{0.5 \text{ kNm/m}}$$

Total

$$M_{total_R} = M_{stem_R} + M_{base_R} + M_{moist_R} + M_{exc_R} = \mathbf{75.8 \text{ kNm/m}}$$

Check stability against overturning

Factor of safety

$$FoS_{ot} = M_{total_R} / M_{total_OT} = \mathbf{2.659}$$

PASS - Maximum restoring moment is greater than overturning moment

Bearing pressure check

Vertical forces on wall

Wall stem

$$F_{stem} = \gamma G \times A_{stem} \times \gamma_{stem} = \mathbf{14.2 \text{ kN/m}}$$

Wall base

$$F_{base} = \gamma G \times A_{base} \times \gamma_{base} = \mathbf{17.2 \text{ kN/m}}$$

Surcharge load

$$F_{sur_v} = \gamma_Q \times \text{Surcharge}_Q \times l_{heel} = \mathbf{5 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma G \times A_{moist} \times \gamma_{mr}' = \mathbf{78.5 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{sur_v} + F_{moist_v} = \mathbf{114.9 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{2.9 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{28.5 \text{ kN/m}}$$

Base soil

$$F_{pass_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b' \times (d_{cover} + h_{base})^2 / 2 = \mathbf{-5.1 \text{ kN/m}}$$

Total

$$F_{total_h} = \max(F_{sur_h} + F_{moist_h} + F_{pass_h} - F_{total_v} \times \tan(\delta_{bb,d}), 0 \text{ kN/m}) = \mathbf{0 \text{ kN/m}}$$

Moments on wall

Wall stem

$$M_{stem} = F_{stem} \times X_{stem} = \mathbf{3.7 \text{ kNm/m}}$$

Wall base

$$M_{base} = F_{base} \times X_{base} = \mathbf{14.6 \text{ kNm/m}}$$

Surcharge load

$$M_{sur} = F_{sur_v} \times X_{sur_v} - F_{sur_h} \times X_{sur_h} = \mathbf{1.4 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist} = F_{moist_v} \times X_{moist_v} - F_{moist_h} \times X_{moist_h} = \mathbf{58.5 \text{ kNm/m}}$$

Base soil

$$M_{pass} = -F_{pass_h} \times X_{pass_h} = \mathbf{0.5 \text{ kNm/m}}$$

Total

$$M_{total} = M_{stem} + M_{base} + M_{sur} + M_{moist} + M_{pass} = \mathbf{78.8 \text{ kNm/m}}$$

Check bearing pressure

Distance to reaction

$$\bar{X} = M_{total} / F_{total_v} = \mathbf{685 \text{ mm}}$$

Project				Job no.	
Calcs for				Start page no./Revision 5	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Eccentricity of reaction	$e = \bar{x} - l_{base} / 2 = -165 \text{ mm}$
Loaded length of base	$l_{load} = 2 \times \bar{x} = 1371 \text{ mm}$
Bearing pressure at toe	$q_{toe} = F_{total_v} / l_{load} = 83.8 \text{ kN/m}^2$
Bearing pressure at heel	$q_{heel} = 0 \text{ kN/m}^2$
Effective overburden pressure	$q = (t_{base} + d_{cover}) \times \gamma_{b'} = 5.4 \text{ kN/m}^2$
Design effective overburden pressure	$q' = q / \gamma_{\gamma} = 5.4 \text{ kN/m}^2$
Bearing resistance factors	$N_q = \text{Exp}(\pi \times \tan(\phi'_{b,d})) \times (\tan(45 \text{ deg} + \phi'_{b,d} / 2))^2 = 33.296$ $N_c = (N_q - 1) \times \cot(\phi'_{b,d}) = 46.124$ $N_{\gamma} = 2 \times (N_q - 1) \times \tan(\phi'_{b,d}) = 45.228$
Foundation shape factors	$s_q = 1$ $s_{\gamma} = 1$ $s_c = 1$
Load inclination factors	$H = F_{sur_h} + F_{moist_h} + F_{pass_h} = 26.2 \text{ kN/m}$ $V = F_{total_v} = 114.9 \text{ kN/m}$ $m = 2$ $i_q = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^m = 0.595$ $i_{\gamma} = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^{(m+1)} = 0.459$ $i_c = i_q - (1 - i_q) / (N_c \times \tan(\phi'_{b,d})) = 0.583$
Net ultimate bearing capacity	$n_f = c'_{b,d} \times N_c \times s_c \times i_c + q' \times N_q \times s_q \times i_q + 0.5 \times \gamma_{b'} \times l_{load} \times N_{\gamma} \times s_{\gamma} \times i_{\gamma} = 363.5 \text{ kN/m}^2$
Factor of safety	$FoS_{bp} = n_f / \max(q_{toe}, q_{heel}) = 4.335$ PASS - Allowable bearing pressure exceeds maximum applied bearing pressure

Design approach 1

Partial factors on actions - Table A.3 - Combination 2

Partial factor set	A2
Permanent unfavourable action	$\gamma_G = 1.000$
Permanent favourable action	$\gamma_{Gf} = 1.000$
Variable unfavourable action	$\gamma_Q = 1.300$
Variable favourable action	$\gamma_{Qf} = 0.000$

Partial factors for soil parameters – Table A.4 - Combination 2

Soil parameter set	M2
Angle of shearing resistance	$\gamma_{\phi'} = 1.25$
Effective cohesion	$\gamma_{c'} = 1.25$
Weight density	$\gamma_{\gamma} = 1.00$

Retained soil properties

Design moist density	$\gamma_{mr}' = \gamma_{mr} / \gamma_{\gamma} = 21 \text{ kN/m}^3$
Design saturated density	$\gamma_{sr}' = \gamma_{sr} / \gamma_{\gamma} = 23 \text{ kN/m}^3$
Design effective shear resistance angle	$\phi'_{r,d} = \text{atan}(\tan(\phi'_{r,k}) / \gamma_{\phi'}) = 29.3 \text{ deg}$
Design wall friction angle	$\delta_{r,d} = \text{atan}(\tan(\delta_{r,k}) / \gamma_{\phi'}) = 14.2 \text{ deg}$

Base soil properties

Design soil density	$\gamma_{b'} = \gamma_b / \gamma_{\gamma} = 18 \text{ kN/m}^3$
Design effective shear resistance angle	$\phi'_{b,d} = \text{atan}(\tan(\phi'_{b,k}) / \gamma_{\phi'}) = 29.3 \text{ deg}$
Design wall friction angle	$\delta_{b,d} = \text{atan}(\tan(\delta_{b,k}) / \gamma_{\phi'}) = 12.1 \text{ deg}$
Design base friction angle	$\delta_{bb,d} = \text{atan}(\tan(\delta_{bb,k}) / \gamma_{\phi'}) = 24.8 \text{ deg}$

Project				Job no.	
Calcs for				Start page no./Revision 6	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Design effective cohesion

$$c'_{b,d} = c'_{b,k} / \gamma_c = \mathbf{0 \text{ kN/m}^2}$$

Using Coulomb theory

Active pressure coefficient

$$K_A = \sin(\alpha + \phi'_{r,d})^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta_{r,d}) \times [1 + \sqrt{[\sin(\phi'_{r,d} + \delta_{r,d}) \times \sin(\phi'_{r,d} - \beta) / (\sin(\alpha - \delta_{r,d}) \times \sin(\alpha + \beta))]}])^2 = \mathbf{0.411}$$

Passive pressure coefficient

$$K_P = \sin(90 - \phi'_{b,d})^2 / (\sin(90 + \delta_{b,d}) \times [1 - \sqrt{[\sin(\phi'_{b,d} + \delta_{b,d}) \times \sin(\phi'_{b,d}) / (\sin(90 + \delta_{b,d}))]}])^2 = \mathbf{4.303}$$

Sliding check

Vertical forces on wall

Wall stem

$$F_{\text{stem}} = \gamma G_f \times A_{\text{stem}} \times \gamma_{\text{stem}} = \mathbf{10.5 \text{ kN/m}}$$

Wall base

$$F_{\text{base}} = \gamma G_f \times A_{\text{base}} \times \gamma_{\text{base}} = \mathbf{12.8 \text{ kN/m}}$$

Moist retained soil

$$F_{\text{moist}_v} = \gamma G_f \times A_{\text{moist}} \times \gamma_{\text{mr}} = \mathbf{58.2 \text{ kN/m}}$$

Total

$$F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} = \mathbf{81.5 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{\text{sur}_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{\text{eff}} = \mathbf{3.4 \text{ kN/m}}$$

Moist retained soil

$$F_{\text{moist}_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{\text{mr}} \times h_{\text{eff}}^2 / 2 = \mathbf{28.4 \text{ kN/m}}$$

Total

$$F_{\text{total}_h} = F_{\text{sur}_h} + F_{\text{moist}_h} = \mathbf{31.8 \text{ kN/m}}$$

Check stability against sliding

Base soil resistance

$$F_{\text{exc}_h} = \gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b \times (h_{\text{pass}} + h_{\text{base}})^2 / 2 = \mathbf{3.4 \text{ kN/m}}$$

Base friction

$$F_{\text{friction}} = F_{\text{total}_v} \times \tan(\delta_{bb,d}) = \mathbf{37.6 \text{ kN/m}}$$

Resistance to sliding

$$F_{\text{rest}} = F_{\text{exc}_h} + F_{\text{friction}} = \mathbf{41 \text{ kN/m}}$$

Factor of safety

$$F_{\text{OSsl}} = F_{\text{rest}} / F_{\text{total}_h} = \mathbf{1.29}$$

PASS - Resistance to sliding is greater than sliding force

Overtipping check

Vertical forces on wall

Wall stem

$$F_{\text{stem}} = \gamma G_f \times A_{\text{stem}} \times \gamma_{\text{stem}} = \mathbf{10.5 \text{ kN/m}}$$

Wall base

$$F_{\text{base}} = \gamma G_f \times A_{\text{base}} \times \gamma_{\text{base}} = \mathbf{12.8 \text{ kN/m}}$$

Moist retained soil

$$F_{\text{moist}_v} = \gamma G_f \times A_{\text{moist}} \times \gamma_{\text{mr}} = \mathbf{58.2 \text{ kN/m}}$$

Total

$$F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} = \mathbf{81.5 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{\text{sur}_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{\text{eff}} = \mathbf{3.4 \text{ kN/m}}$$

Moist retained soil

$$F_{\text{moist}_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{\text{mr}} \times h_{\text{eff}}^2 / 2 = \mathbf{28.4 \text{ kN/m}}$$

Base soil

$$F_{\text{exc}_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b \times (h_{\text{pass}} + h_{\text{base}})^2 / 2 = \mathbf{-3.4 \text{ kN/m}}$$

Total

$$F_{\text{total}_h} = F_{\text{sur}_h} + F_{\text{moist}_h} + F_{\text{exc}_h} = \mathbf{28.4 \text{ kN/m}}$$

Overtipping moments on wall

Surcharge load

$$M_{\text{sur}_OT} = F_{\text{sur}_h} \times X_{\text{sur}_h} = \mathbf{4.4 \text{ kNm/m}}$$

Moist retained soil

$$M_{\text{moist}_OT} = F_{\text{moist}_h} \times X_{\text{moist}_h} = \mathbf{24.7 \text{ kNm/m}}$$

Total

$$M_{\text{total}_OT} = M_{\text{sur}_OT} + M_{\text{moist}_OT} = \mathbf{29.1 \text{ kNm/m}}$$

Restoring moments on wall

Wall stem

$$M_{\text{stem}_R} = F_{\text{stem}} \times X_{\text{stem}} = \mathbf{2.8 \text{ kNm/m}}$$

Wall base

$$M_{\text{base}_R} = F_{\text{base}} \times X_{\text{base}} = \mathbf{10.8 \text{ kNm/m}}$$

Moist retained soil

$$M_{\text{moist}_R} = F_{\text{moist}_v} \times X_{\text{moist}_v} = \mathbf{61.7 \text{ kNm/m}}$$

Base soil

$$M_{\text{exc}_R} = -F_{\text{exc}_h} \times X_{\text{exc}_h} = \mathbf{0.3 \text{ kNm/m}}$$

Total

$$M_{\text{total}_R} = M_{\text{stem}_R} + M_{\text{base}_R} + M_{\text{moist}_R} + M_{\text{exc}_R} = \mathbf{75.6 \text{ kNm/m}}$$

Project				Job no.	
Calcs for				Start page no./Revision 7	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Check stability against overturning

Factor of safety

$$FoS_{ot} = M_{total_R} / M_{total_OT} = \mathbf{2.599}$$

PASS - Maximum restoring moment is greater than overturning moment

Bearing pressure check

Vertical forces on wall

Wall stem

$$F_{stem} = \gamma_G \times A_{stem} \times \gamma_{stem} = \mathbf{10.5 \text{ kN/m}}$$

Wall base

$$F_{base} = \gamma_G \times A_{base} \times \gamma_{base} = \mathbf{12.8 \text{ kN/m}}$$

Surcharge load

$$F_{sur_v} = \gamma_Q \times \text{Surcharge}_Q \times l_{heel} = \mathbf{4.3 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma_G \times A_{moist} \times \gamma_{mr}' = \mathbf{58.2 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{sur_v} + F_{moist_v} = \mathbf{85.8 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{3.4 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma_G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{28.4 \text{ kN/m}}$$

Base soil

$$F_{pass_h} = -\gamma_G \times K_P \times \cos(\delta_{b,d}) \times \gamma_{b'} \times (d_{cover} + h_{base})^2 / 2 = \mathbf{-3.4 \text{ kN/m}}$$

Total

$$F_{total_h} = \max(F_{sur_h} + F_{moist_h} + F_{pass_h} - F_{total_v} \times \tan(\delta_{bb,d}), 0 \text{ kN/m}) = \mathbf{0 \text{ kN/m}}$$

Moments on wall

Wall stem

$$M_{stem} = F_{stem} \times X_{stem} = \mathbf{2.8 \text{ kNm/m}}$$

Wall base

$$M_{base} = F_{base} \times X_{base} = \mathbf{10.8 \text{ kNm/m}}$$

Surcharge load

$$M_{sur} = F_{sur_v} \times X_{sur_v} - F_{sur_h} \times X_{sur_h} = \mathbf{0.1 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist} = F_{moist_v} \times X_{moist_v} - F_{moist_h} \times X_{moist_h} = \mathbf{37 \text{ kNm/m}}$$

Base soil

$$M_{pass} = -F_{pass_h} \times X_{pass_h} = \mathbf{0.3 \text{ kNm/m}}$$

Total

$$M_{total} = M_{stem} + M_{base} + M_{sur} + M_{moist} + M_{pass} = \mathbf{51 \text{ kNm/m}}$$

Check bearing pressure

Distance to reaction

$$\bar{x} = M_{total} / F_{total_v} = \mathbf{594 \text{ mm}}$$

Eccentricity of reaction

$$e = \bar{x} - l_{base} / 2 = \mathbf{-256 \text{ mm}}$$

Loaded length of base

$$l_{load} = 2 \times \bar{x} = \mathbf{1189 \text{ mm}}$$

Bearing pressure at toe

$$q_{toe} = F_{total_v} / l_{load} = \mathbf{72.1 \text{ kN/m}^2}$$

Bearing pressure at heel

$$q_{heel} = \mathbf{0 \text{ kN/m}^2}$$

Effective overburden pressure

$$q = (t_{base} + d_{cover}) \times \gamma_{b'} = \mathbf{5.4 \text{ kN/m}^2}$$

Design effective overburden pressure

$$q' = q / \gamma_r = \mathbf{5.4 \text{ kN/m}^2}$$

Bearing resistance factors

$$N_q = \text{Exp}(\pi \times \tan(\phi'_{b,d})) \times (\tan(45 \text{ deg} + \phi'_{b,d} / 2))^2 = \mathbf{16.921}$$

$$N_c = (N_q - 1) \times \cot(\phi'_{b,d}) = \mathbf{28.422}$$

$$N_\gamma = 2 \times (N_q - 1) \times \tan(\phi'_{b,d}) = \mathbf{17.837}$$

Foundation shape factors

$$s_q = 1$$

$$s_\gamma = 1$$

$$s_c = 1$$

Load inclination factors

$$H = F_{sur_h} + F_{moist_h} + F_{pass_h} = \mathbf{28.4 \text{ kN/m}}$$

$$V = F_{total_v} = \mathbf{85.8 \text{ kN/m}}$$

$$m = 2$$

$$i_q = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^m = \mathbf{0.447}$$

$$i_\gamma = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^{(m+1)} = \mathbf{0.299}$$

$$i_c = i_q - (1 - i_q) / (N_c \times \tan(\phi'_{b,d})) = \mathbf{0.413}$$

Net ultimate bearing capacity

Project				Job no.	
Calcs for				Start page no./Revision 8	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

$$n_f = c'_{b,d} \times N_c \times S_c \times i_c + q' \times N_q \times S_q \times i_q + 0.5 \times \gamma_b' \times I_{load} \times N_\gamma \times S_\gamma \times i_\gamma = \mathbf{98 \text{ kN/m}^2}$$

Factor of safety

$$FoS_{bp} = n_f / \max(q_{toe}, q_{heel}) = \mathbf{1.358}$$

PASS - Allowable bearing pressure exceeds maximum applied bearing pressure

RETAINING WALL DESIGN

In accordance with EN1992-1-1:2004 incorporating Corrigendum dated January 2008 and the UK National Annex incorporating National Amendment No.1

Tedds calculation version 2.9.22

Concrete details - Table 3.1 - Strength and deformation characteristics for concrete

Concrete strength class	C30/37
Characteristic compressive cylinder strength	$f_{ck} = \mathbf{30 \text{ N/mm}^2}$
Characteristic compressive cube strength	$f_{ck,cube} = \mathbf{37 \text{ N/mm}^2}$
Mean value of compressive cylinder strength	$f_{cm} = f_{ck} + 8 \text{ N/mm}^2 = \mathbf{38 \text{ N/mm}^2}$
Mean value of axial tensile strength	$f_{ctm} = 0.3 \text{ N/mm}^2 \times (f_{ck} / 1 \text{ N/mm}^2)^{2/3} = \mathbf{2.9 \text{ N/mm}^2}$
5% fractile of axial tensile strength	$f_{ctk,0.05} = 0.7 \times f_{ctm} = \mathbf{2.0 \text{ N/mm}^2}$
Secant modulus of elasticity of concrete	$E_{cm} = 22 \text{ kN/mm}^2 \times (f_{cm} / 10 \text{ N/mm}^2)^{0.3} = \mathbf{32837 \text{ N/mm}^2}$
Partial factor for concrete - Table 2.1N	$\gamma_C = \mathbf{1.50}$
Compressive strength coefficient - cl.3.1.6(1)	$\alpha_{cc} = \mathbf{0.85}$
Design compressive concrete strength - exp.3.15	$f_{cd} = \alpha_{cc} \times f_{ck} / \gamma_C = \mathbf{17.0 \text{ N/mm}^2}$
Maximum aggregate size	$h_{agg} = \mathbf{20 \text{ mm}}$
Ultimate strain - Table 3.1	$\epsilon_{cu2} = \mathbf{0.0035}$
Shortening strain - Table 3.1	$\epsilon_{cu3} = \mathbf{0.0035}$
Effective compression zone height factor	$\lambda = \mathbf{0.80}$
Effective strength factor	$\eta = \mathbf{1.00}$
Bending coefficient k_1	$K_1 = \mathbf{0.40}$
Bending coefficient k_2	$K_2 = 1.00 \times (0.6 + 0.0014/\epsilon_{cu2}) = \mathbf{1.00}$
Bending coefficient k_3	$K_3 = \mathbf{0.40}$
Bending coefficient k_4	$K_4 = 1.00 \times (0.6 + 0.0014/\epsilon_{cu2}) = \mathbf{1.00}$







Reinforcement details

Characteristic yield strength of reinforcement	$f_{yk} = \mathbf{500 \text{ N/mm}^2}$
Modulus of elasticity of reinforcement	$E_s = \mathbf{200000 \text{ N/mm}^2}$
Partial factor for reinforcing steel - Table 2.1N	$\gamma_S = \mathbf{1.15}$
Design yield strength of reinforcement	$f_{yd} = f_{yk} / \gamma_S = \mathbf{435 \text{ N/mm}^2}$

Cover to reinforcement

Front face of stem	$c_{sf} = \mathbf{40 \text{ mm}}$
Rear face of stem	$c_{sr} = \mathbf{50 \text{ mm}}$
Top face of base	$c_{bt} = \mathbf{50 \text{ mm}}$
Bottom face of base	$c_{bb} = \mathbf{75 \text{ mm}}$

Project				Job no.	
Calcs for				Start page no./Revision 9	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date



Check stem design at base of stem

Depth of section

$h = 225 \text{ mm}$

Rectangular section in flexure - Section 6.1

Design bending moment combination 2

$M = 11.5 \text{ kNm/m}$

Depth to tension reinforcement

$d = h - c_{sr} - \phi_{sr} / 2 = 170 \text{ mm}$

$K = M / (d^2 \times f_{ck}) = 0.013$

$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$

$K' = 0.207$

$K' > K$ - No compression reinforcement is required

Lever arm

$z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 161 \text{ mm}$

Depth of neutral axis

$x = 2.5 \times (d - z) = 21 \text{ mm}$

Area of tension reinforcement required

$A_{sr,req} = M / (f_{yd} \times z) = 164 \text{ mm}^2/\text{m}$

Tension reinforcement provided

10 dia.bars @ 200 c/c



Project				Job no.	
Calcs for				Start page no./Revision 10	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Area of tension reinforcement provided

$$A_{sr,prov} = \pi \times \phi_{sr}^2 / (4 \times s_{sr}) = \mathbf{393 \text{ mm}^2/m}$$

Minimum area of reinforcement - exp.9.1N

$$A_{sr,min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = \mathbf{256 \text{ mm}^2/m}$$

Maximum area of reinforcement - cl.9.2.1.1(3)

$$A_{sr,max} = 0.04 \times h = \mathbf{9000 \text{ mm}^2/m}$$

$$\max(A_{sr,req}, A_{sr,min}) / A_{sr,prov} = \mathbf{0.652}$$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Deflection control - Section 7.4

Reference reinforcement ratio

$$\rho_0 = \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} / 1000 = \mathbf{0.005}$$

Required tension reinforcement ratio

$$\rho = A_{sr,req} / d = \mathbf{0.001}$$

Required compression reinforcement ratio

$$\rho' = A_{sr,2,req} / d_2 = \mathbf{0.000}$$

Structural system factor - Table 7.4N

$$K_b = \mathbf{0.4}$$

Reinforcement factor - exp.7.17

$$K_s = \min(500 \text{ N/mm}^2 / (f_{yk} \times A_{sr,req} / A_{sr,prov}), 1.5) = \mathbf{1.5}$$

Limiting span to depth ratio - exp.7.16.a

$$\min(K_s \times K_b \times [11 + 1.5 \times \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} \times \rho_0 / \rho + 3.2 \times \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} \times (\rho_0 / \rho - 1)^{3/2}], 40 \times K_b) = \mathbf{16}$$

Actual span to depth ratio

$$h_{stem} / d = \mathbf{11}$$

PASS - Span to depth ratio is less than deflection control limit

Crack control - Section 7.3

Limiting crack width

$$w_{max} = \mathbf{0.3 \text{ mm}}$$

Variable load factor - EN1990 – Table A1.1

$$\psi_2 = \mathbf{0.6}$$

Serviceability bending moment

$$M_{sls} = \mathbf{7.6 \text{ kNm/m}}$$

Tensile stress in reinforcement

$$\sigma_s = M_{sls} / (A_{sr,prov} \times z) = \mathbf{120 \text{ N/mm}^2}$$

Load duration

Long term

Load duration factor

$$k_t = \mathbf{0.4}$$

Effective area of concrete in tension

$$A_{c,eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$$

$$A_{c,eff} = \mathbf{67917 \text{ mm}^2/m}$$

Mean value of concrete tensile strength

$$f_{ct,eff} = f_{ctm} = \mathbf{2.9 \text{ N/mm}^2}$$

Reinforcement ratio

$$\rho_{p,eff} = A_{sr,prov} / A_{c,eff} = \mathbf{0.006}$$

Modular ratio

$$\alpha_e = E_s / E_{cm} = \mathbf{6.091}$$

Bond property coefficient

$$k_1 = \mathbf{0.8}$$

Strain distribution coefficient

$$k_2 = \mathbf{0.5}$$

$$k_3 = \mathbf{3.4}$$

$$k_4 = \mathbf{0.425}$$

Maximum crack spacing - exp.7.11

$$s_{r,max} = k_3 \times C_{sr} + k_1 \times k_2 \times k_4 \times \phi_{sr} / \rho_{p,eff} = \mathbf{464 \text{ mm}}$$

Maximum crack width - exp.7.8

$$w_k = s_{r,max} \times \max(\sigma_s - k_t \times (f_{ct,eff} / \rho_{p,eff}) \times (1 + \alpha_e \times \rho_{p,eff}), 0.6 \times \sigma_s) / E_s$$

$$w_k = \mathbf{0.167 \text{ mm}}$$

$$w_k / w_{max} = \mathbf{0.557}$$

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$$V = \mathbf{17.2 \text{ kN/m}}$$

$$C_{Rd,c} = 0.18 / \gamma_c = \mathbf{0.120}$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = \mathbf{2.000}$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{sr,prov} / d, 0.02) = \mathbf{0.002}$$

$$v_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = \mathbf{0.542 \text{ N/mm}^2}$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, v_{min}) \times d$$

$$V_{Rd,c} = \mathbf{92.2 \text{ kN/m}}$$

$$V / V_{Rd,c} = \mathbf{0.186}$$



Project				Job no.	
Calcs for				Start page no./Revision 11	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

PASS - Design shear resistance exceeds design shear force

Horizontal reinforcement parallel to face of stem - Section 9.6

Minimum area of reinforcement – cl.9.6.3(1) $A_{sx.req} = \max(0.25 \times A_{sr.prov}, 0.001 \times t_{stem}) = 225 \text{ mm}^2/\text{m}$

Maximum spacing of reinforcement – cl.9.6.3(2) $S_{sx.max} = 400 \text{ mm}$

Transverse reinforcement provided 10 dia.bars @ 200 c/c

Area of transverse reinforcement provided $A_{sx.prov} = \pi \times \phi_{sx}^2 / (4 \times s_{sx}) = 393 \text{ mm}^2/\text{m}$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Check base design at toe

Depth of section $h = 300 \text{ mm}$

Rectangular section in flexure - Section 6.1

Design bending moment combination 1 $M = 1.8 \text{ kNm/m}$

Depth to tension reinforcement $d = h - C_{bb} - \phi_{bb} / 2 = 219 \text{ mm}$

$K = M / (d^2 \times f_{ck}) = 0.001$

$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$

$K' = 0.207$

$K' > K$ - No compression reinforcement is required

Lever arm $z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 208 \text{ mm}$

Depth of neutral axis $x = 2.5 \times (d - z) = 27 \text{ mm}$

Area of tension reinforcement required $A_{bb.req} = M / (f_{yd} \times z) = 20 \text{ mm}^2/\text{m}$

Tension reinforcement provided 12 dia.bars @ 200 c/c

Area of tension reinforcement provided $A_{bb.prov} = \pi \times \phi_{bb}^2 / (4 \times S_{bb}) = 565 \text{ mm}^2/\text{m}$

Minimum area of reinforcement - exp.9.1N $A_{bb.min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = 330 \text{ mm}^2/\text{m}$

Maximum area of reinforcement - cl.9.2.1.1(3) $A_{bb.max} = 0.04 \times h = 12000 \text{ mm}^2/\text{m}$

$\max(A_{bb.req}, A_{bb.min}) / A_{bb.prov} = 0.583$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Crack control - Section 7.3

Limiting crack width $w_{max} = 0.3 \text{ mm}$

Variable load factor - EN1990 – Table A1.1 $\psi_2 = 0.6$

Serviceability bending moment $M_{sls} = 1.3 \text{ kNm/m}$

Tensile stress in reinforcement $\sigma_s = M_{sls} / (A_{bb.prov} \times z) = 11 \text{ N/mm}^2$

Load duration Long term

Load duration factor $k_t = 0.4$

Effective area of concrete in tension $A_{c.eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$

$A_{c.eff} = 90875 \text{ mm}^2/\text{m}$

Mean value of concrete tensile strength $f_{ct.eff} = f_{ctm} = 2.9 \text{ N/mm}^2$

Reinforcement ratio $\rho_{p.eff} = A_{bb.prov} / A_{c.eff} = 0.006$

Modular ratio $\alpha_e = E_s / E_{cm} = 6.091$

Bond property coefficient $k_1 = 0.8$

Strain distribution coefficient $k_2 = 0.5$

$k_3 = 3.4$

$k_4 = 0.425$

Maximum crack spacing - exp.7.11 $S_{r.max} = k_3 \times C_{bb} + k_1 \times k_2 \times k_4 \times \phi_{bb} / \rho_{p.eff} = 583 \text{ mm}$

Maximum crack width - exp.7.8 $w_k = S_{r.max} \times \max(\sigma_s - k_t \times (f_{ct.eff} / \rho_{p.eff}) \times (1 + \alpha_e \times \rho_{p.eff}), 0.6 \times \sigma_s) / E_s$

$w_k = 0.019 \text{ mm}$

$w_k / w_{max} = 0.064$



Project				Job no.	
Calcs for				Start page no./Revision 12	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$$V = 14.7 \text{ kN/m}$$

$$C_{Rd,c} = 0.18 / \gamma_c = 0.120$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = 1.956$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{bb,prov} / d, 0.02) = 0.003$$

$$V_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = 0.524 \text{ N/mm}^2$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, V_{min}) \times d$$

$$V_{Rd,c} = 114.8 \text{ kN/m}$$

$$V / V_{Rd,c} = 0.128$$

PASS - Design shear resistance exceeds design shear force

Check base design at heel

Depth of section

$$h = 300 \text{ mm}$$

Rectangular section in flexure - Section 6.1

Design bending moment combination 2

$$M = 10.2 \text{ kNm/m}$$

Depth to tension reinforcement

$$d = h - c_{bt} - \phi_{bt} / 2 = 244 \text{ mm}$$

$$K = M / (d^2 \times f_{ck}) = 0.006$$

$$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$$

$$K' = 0.207$$

$K' > K$ - No compression reinforcement is required

Lever arm

$$z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 232 \text{ mm}$$

Depth of neutral axis

$$x = 2.5 \times (d - z) = 31 \text{ mm}$$

Area of tension reinforcement required

$$A_{bt,req} = M / (f_{yd} \times z) = 101 \text{ mm}^2/\text{m}$$

Tension reinforcement provided

$$12 \text{ dia. bars @ } 200 \text{ c/c}$$

Area of tension reinforcement provided

$$A_{bt,prov} = \pi \times \phi_{bt}^2 / (4 \times s_{bt}) = 565 \text{ mm}^2/\text{m}$$

Minimum area of reinforcement - exp.9.1N

$$A_{bt,min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = 368 \text{ mm}^2/\text{m}$$

Maximum area of reinforcement - cl.9.2.1.1(3)

$$A_{bt,max} = 0.04 \times h = 12000 \text{ mm}^2/\text{m}$$

$$\max(A_{bt,req}, A_{bt,min}) / A_{bt,prov} = 0.65$$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Crack control - Section 7.3

Limiting crack width

$$w_{max} = 0.3 \text{ mm}$$

Variable load factor - EN1990 – Table A1.1

$$\psi_2 = 0.6$$

Serviceability bending moment

$$M_{sls} = 6.2 \text{ kNm/m}$$

Tensile stress in reinforcement

$$\sigma_s = M_{sls} / (A_{bt,prov} \times z) = 47 \text{ N/mm}^2$$

Load duration

Long term

Load duration factor

$$k_t = 0.4$$

Effective area of concrete in tension

$$A_{c,eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$$

$$A_{c,eff} = 89833 \text{ mm}^2/\text{m}$$

Mean value of concrete tensile strength

$$f_{ct,eff} = f_{ctm} = 2.9 \text{ N/mm}^2$$

Reinforcement ratio

$$\rho_{p,eff} = A_{bt,prov} / A_{c,eff} = 0.006$$

Modular ratio

$$\alpha_e = E_s / E_{cm} = 6.091$$

Bond property coefficient

$$k_1 = 0.8$$

Strain distribution coefficient

$$k_2 = 0.5$$

$$k_3 = 3.4$$

$$k_4 = 0.425$$

Project				Job no.	
Calcs for				Start page no./Revision 13	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Maximum crack spacing - exp.7.11

$$s_{r,max} = k_3 \times C_{bt} + k_1 \times k_2 \times k_4 \times \phi_{bt} / \rho_{p,eff} = \mathbf{494 \text{ mm}}$$

Maximum crack width - exp.7.8

$$w_k = s_{r,max} \times \max(\sigma_s - k_t \times (f_{ct,eff} / \rho_{p,eff}) \times (1 + \alpha_e \times \rho_{p,eff}), 0.6 \times \sigma_s) / E_s$$

$$w_k = \mathbf{0.07 \text{ mm}}$$

$$w_k / w_{max} = \mathbf{0.232}$$

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$$V = \mathbf{9.8 \text{ kN/m}}$$

$$C_{Rd,c} = 0.18 / \gamma_c = \mathbf{0.120}$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = \mathbf{1.905}$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{bt,prov} / d, 0.02) = \mathbf{0.002}$$

$$v_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = \mathbf{0.504 \text{ N/mm}^2}$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, v_{min}) \times d$$

$$V_{Rd,c} = \mathbf{123 \text{ kN/m}}$$

$$V / V_{Rd,c} = \mathbf{0.080}$$

PASS - Design shear resistance exceeds design shear force

Secondary transverse reinforcement to base - Section 9.3

Minimum area of reinforcement – cl.9.3.1.1(2)

$$A_{bx,req} = 0.2 \times A_{bb,prov} = \mathbf{113 \text{ mm}^2/\text{m}}$$

Maximum spacing of reinforcement – cl.9.3.1.1(3)

$$s_{bx,max} = \mathbf{450 \text{ mm}}$$


Transverse reinforcement provided

$$\mathbf{10 \text{ dia. bars @ } 200 \text{ c/c}}$$

Area of transverse reinforcement provided

$$A_{bx,prov} = \pi \times \phi_{bx}^2 / (4 \times s_{bx}) = \mathbf{393 \text{ mm}^2/\text{m}}$$

PASS - Area of reinforcement provided is greater than area of reinforcement required



Reinforcement details



Tekla® Tedds

Shear Design
7 Ash Tree Court
Cardiff Gate Business Park
CF23 8RW

Project				Job no.	
Calcs for				Start page no./Revision 14	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

--	--	--	--	--	--

Project				Job no.	
Calcs for				Start page no./Revision 1	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

RETAINING WALL ANALYSIS

In accordance with EN1997-1:2004 incorporating Corrigendum dated February 2009 and the UK National Annex incorporating Corrigendum No.1

Tedds calculation version 2.9.22

Analysis summary

Design summary

Overall design utilisation 0.774
Overall design status Pass

Description	Unit	Capacity	Applied	F o S	Result
Sliding stability	kN/m	32.9	25.5	1.292	PASS
Overturning stability	kNm/m	52.6	20.8	2.529	PASS
Bearing pressure	kN/m ²	92.6	64.6	1.433	PASS

Design summary

Description	Unit	Provided	Required	Utilisation	Result
Shear resistance	kN/m	114.8	11.6	0.101	PASS
Base top face - Flexural reinforcement	mm ² /m	565.5	367.5	0.650	PASS
Base bottom face - Flexural reinforcement	mm ² /m	565.5	329.8	0.583	PASS
Base - Shear resistance	kN/m	114.8	11.6	0.101	PASS
Min. transverse stem reinf.	mm ² /m	392.7	225.0	0.573	PASS
Min. transverse base reinf.	mm ² /m	392.7	113.1	0.288	PASS

Retaining wall details

Stem type Cantilever
Stem height $h_{\text{stem}} = 1650$ mm
Stem thickness $t_{\text{stem}} = 225$ mm
Angle to rear face of stem $\alpha = 90$ deg
Stem density $\gamma_{\text{stem}} = 25$ kN/m³
Toe length $l_{\text{toe}} = 150$ mm
Heel length $l_{\text{heel}} = 1125$ mm
Base thickness $t_{\text{base}} = 300$ mm
Base density $\gamma_{\text{base}} = 25$ kN/m³
Height of retained soil $h_{\text{ret}} = 1650$ mm
Angle of soil surface $\beta = 18$ deg
Depth of cover $d_{\text{cover}} = 0$ mm

Retained soil properties

Soil type Medium dense well graded sand
Moist density $\gamma_{\text{mr}} = 21$ kN/m³
Saturated density $\gamma_{\text{sr}} = 23$ kN/m³
Characteristic effective shear resistance angle $\phi'_{r,k} = 35$ deg
Characteristic wall friction angle $\delta_{r,k} = 17.5$ deg

Base soil properties


Soil type Medium dense well graded sand
Soil density $\gamma_b = 18$ kN/m³
Characteristic cohesion $c'_{b,k} = 0$ kN/m²
Characteristic effective shear resistance angle $\phi'_{b,k} = 35$ deg
Characteristic wall friction angle $\delta_{b,k} = 15$ deg
Characteristic base friction angle $\delta_{bb,k} = 30$ deg

Project				Job no.	
Calcs for				Start page no./Revision 2	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Loading details

Variable surcharge load

Surcharge₀ = 2.5 kN/m²



General arrangement - sketch pressures relate to bearing check

Calculate retaining wall geometry

Base length	$l_{base} = l_{toe} + t_{stem} + l_{heel} = 1500 \text{ mm}$
Moist soil height	$h_{moist} = h_{soil} = 1650 \text{ mm}$
Length of surcharge load	$l_{sur} = l_{heel} = 1125 \text{ mm}$
- Distance to vertical component	$x_{sur_v} = l_{base} - l_{heel} / 2 = 938 \text{ mm}$
Effective height of wall	$h_{eff} = h_{base} + d_{cover} + h_{ret} + l_{sur} \times \tan(\beta) = 2316 \text{ mm}$
- Distance to horizontal component	$x_{sur_h} = h_{eff} / 2 = 1158 \text{ mm}$
Area of wall stem	$A_{stem} = h_{stem} \times t_{stem} = 0.371 \text{ m}^2$
- Distance to vertical component	$x_{stem} = l_{toe} + t_{stem} / 2 = 263 \text{ mm}$
Area of wall base	$A_{base} = l_{base} \times t_{base} = 0.45 \text{ m}^2$
- Distance to vertical component	$x_{base} = l_{base} / 2 = 750 \text{ mm}$
Area of moist soil	$A_{moist} = h_{moist} \times l_{heel} + \tan(\beta) \times l_{heel}^2 / 2 = 2.062 \text{ m}^2$
- Distance to vertical component	$x_{moist_v} = l_{base} - (h_{moist} \times l_{heel}^2 / 2 + \tan(\beta) \times l_{heel}^3 / 6) / A_{moist} = 956 \text{ mm}$
- Distance to horizontal component	$x_{moist_h} = h_{eff} / 3 = 772 \text{ mm}$

Design approach 1

Partial factors on actions - Table A.3 - Combination 1

Partial factor set	A1
Permanent unfavourable action	$\gamma_G = 1.350$
Permanent favourable action	$\gamma_{Gf} = 1.000$

Project				Job no.	
Calcs for				Start page no./Revision 3	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Variable unfavourable action $\gamma_Q = 1.500$
Variable favourable action $\gamma_{Qf} = 0.000$

Partial factors for soil parameters – Table A.4 - Combination 1

Soil parameter set **M1**
Angle of shearing resistance $\gamma_{\phi'} = 1.00$
Effective cohesion $\gamma_{c'} = 1.00$
Weight density $\gamma_{\gamma} = 1.00$

Retained soil properties

Design moist density $\gamma_{mr'} = \gamma_{mr} / \gamma_{\gamma} = 21 \text{ kN/m}^3$
Design saturated density $\gamma_{sr'} = \gamma_{sr} / \gamma_{\gamma} = 23 \text{ kN/m}^3$
Design effective shear resistance angle $\phi'_{r,d} = \text{atan}(\tan(\phi'_{r,k}) / \gamma_{\phi'}) = 35 \text{ deg}$
Design wall friction angle $\delta_{r,d} = \text{atan}(\tan(\delta_{r,k}) / \gamma_{\phi'}) = 17.5 \text{ deg}$

Base soil properties

Design soil density $\gamma_{b'} = \gamma_b / \gamma_{\gamma} = 18 \text{ kN/m}^3$
Design effective shear resistance angle $\phi'_{b,d} = \text{atan}(\tan(\phi'_{b,k}) / \gamma_{\phi'}) = 35 \text{ deg}$
Design wall friction angle $\delta_{b,d} = \text{atan}(\tan(\delta_{b,k}) / \gamma_{\phi'}) = 15 \text{ deg}$
Design base friction angle $\delta_{bb,d} = \text{atan}(\tan(\delta_{bb,k}) / \gamma_{\phi'}) = 30 \text{ deg}$
Design effective cohesion $c'_{b,d} = c'_{b,k} / \gamma_{c'} = 0 \text{ kN/m}^2$

Using Coulomb theory

Active pressure coefficient $K_A = \sin(\alpha + \phi'_{r,d})^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta_{r,d}) \times [1 + \sqrt{[\sin(\phi'_{r,d} + \delta_{r,d}) \times \sin(\phi'_{r,d} - \beta) / (\sin(\alpha - \delta_{r,d}) \times \sin(\alpha + \beta))]}]) = 0.310$
Passive pressure coefficient $K_P = \sin(90 - \phi'_{b,d})^2 / (\sin(90 + \delta_{b,d}) \times [1 - \sqrt{[\sin(\phi'_{b,d} + \delta_{b,d}) \times \sin(\phi'_{b,d}) / (\sin(90 + \delta_{b,d}))]}]) = 6.555$

Sliding check

Vertical forces on wall

Wall stem $F_{stem} = \gamma_{Gf} \times A_{stem} \times \gamma_{stem} = 9.3 \text{ kN/m}$
Wall base $F_{base} = \gamma_{Gf} \times A_{base} \times \gamma_{base} = 11.3 \text{ kN/m}$
Moist retained soil $F_{moist_v} = \gamma_{Gf} \times A_{moist} \times \gamma_{mr'} = 43.3 \text{ kN/m}$
Total $F_{total_v} = F_{stem} + F_{base} + F_{moist_v} = 63.8 \text{ kN/m}$

Horizontal forces on wall

Surcharge load $F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = 2.6 \text{ kN/m}$
Moist retained soil $F_{moist_h} = \gamma_G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr'} \times h_{eff}^2 / 2 = 22.5 \text{ kN/m}$
Total $F_{total_h} = F_{sur_h} + F_{moist_h} = 25.1 \text{ kN/m}$

Check stability against sliding

Base soil resistance $F_{exc_h} = \gamma_{Gf} \times K_P \times \cos(\delta_{b,d}) \times \gamma_{b'} \times (h_{pass} + h_{base})^2 / 2 = 5.1 \text{ kN/m}$
Base friction $F_{friction} = F_{total_v} \times \tan(\delta_{bb,d}) = 36.9 \text{ kN/m}$
Resistance to sliding $F_{rest} = F_{exc_h} + F_{friction} = 42 \text{ kN/m}$
Factor of safety $FoS_{sl} = F_{rest} / F_{total_h} = 1.675$

PASS - Resistance to sliding is greater than sliding force

Overturning check

Vertical forces on wall

Wall stem $F_{stem} = \gamma_{Gf} \times A_{stem} \times \gamma_{stem} = 9.3 \text{ kN/m}$

Project				Job no.	
Calcs for				Start page no./Revision 4	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Wall base

$$F_{base} = \gamma G_f \times A_{base} \times \gamma_{base} = \mathbf{11.3 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma G_f \times A_{moist} \times \gamma_{mr}' = \mathbf{43.3 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{moist_v} = \mathbf{63.8 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{2.6 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{22.5 \text{ kN/m}}$$

Base soil

$$F_{exc_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b' \times (h_{pass} + h_{base})^2 / 2 = \mathbf{-5.1 \text{ kN/m}}$$

Total

$$F_{total_h} = F_{sur_h} + F_{moist_h} + F_{exc_h} = \mathbf{19.9 \text{ kN/m}}$$

Overturning moments on wall

Surcharge load

$$M_{sur_OT} = F_{sur_h} \times X_{sur_h} = \mathbf{3 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist_OT} = F_{moist_h} \times X_{moist_h} = \mathbf{17.4 \text{ kNm/m}}$$

Total

$$M_{total_OT} = M_{sur_OT} + M_{moist_OT} = \mathbf{20.3 \text{ kNm/m}}$$

Restoring moments on wall

Wall stem

$$M_{stem_R} = F_{stem} \times X_{stem} = \mathbf{2.4 \text{ kNm/m}}$$

Wall base

$$M_{base_R} = F_{base} \times X_{base} = \mathbf{8.4 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist_R} = F_{moist_v} \times X_{moist_v} = \mathbf{41.4 \text{ kNm/m}}$$

Base soil

$$M_{exc_R} = -F_{exc_h} \times X_{exc_h} = \mathbf{0.5 \text{ kNm/m}}$$

Total

$$M_{total_R} = M_{stem_R} + M_{base_R} + M_{moist_R} + M_{exc_R} = \mathbf{52.8 \text{ kNm/m}}$$

Check stability against overturning

Factor of safety

$$FoS_{ot} = M_{total_R} / M_{total_OT} = \mathbf{2.596}$$

PASS - Maximum restoring moment is greater than overturning moment

Bearing pressure check

Vertical forces on wall

Wall stem

$$F_{stem} = \gamma G \times A_{stem} \times \gamma_{stem} = \mathbf{12.5 \text{ kN/m}}$$

Wall base

$$F_{base} = \gamma G \times A_{base} \times \gamma_{base} = \mathbf{15.2 \text{ kN/m}}$$

Surcharge load

$$F_{sur_v} = \gamma_Q \times \text{Surcharge}_Q \times l_{heel} = \mathbf{4.2 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma G \times A_{moist} \times \gamma_{mr}' = \mathbf{58.5 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{sur_v} + F_{moist_v} = \mathbf{90.4 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{2.6 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{22.5 \text{ kN/m}}$$

Base soil

$$F_{pass_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b' \times (d_{cover} + h_{base})^2 / 2 = \mathbf{-5.1 \text{ kN/m}}$$

Total

$$F_{total_h} = \max(F_{sur_h} + F_{moist_h} + F_{pass_h} - F_{total_v} \times \tan(\delta_{bb,d}), 0 \text{ kN/m}) = \mathbf{0 \text{ kN/m}}$$

Moments on wall

Wall stem

$$M_{stem} = F_{stem} \times X_{stem} = \mathbf{3.3 \text{ kNm/m}}$$

Wall base

$$M_{base} = F_{base} \times X_{base} = \mathbf{11.4 \text{ kNm/m}}$$

Surcharge load

$$M_{sur} = F_{sur_v} \times X_{sur_v} - F_{sur_h} \times X_{sur_h} = \mathbf{1 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist} = F_{moist_v} \times X_{moist_v} - F_{moist_h} \times X_{moist_h} = \mathbf{38.5 \text{ kNm/m}}$$

Base soil

$$M_{pass} = -F_{pass_h} \times X_{pass_h} = \mathbf{0.5 \text{ kNm/m}}$$

Total

$$M_{total} = M_{stem} + M_{base} + M_{sur} + M_{moist} + M_{pass} = \mathbf{54.7 \text{ kNm/m}}$$

Check bearing pressure

Distance to reaction

$$\bar{X} = M_{total} / F_{total_v} = \mathbf{605 \text{ mm}}$$

Project				Job no.	
Calcs for				Start page no./Revision 5	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Eccentricity of reaction	$e = \bar{x} - l_{base} / 2 = -145 \text{ mm}$
Loaded length of base	$l_{load} = 2 \times \bar{x} = 1210 \text{ mm}$
Bearing pressure at toe	$q_{toe} = F_{total_v} / l_{load} = 74.7 \text{ kN/m}^2$
Bearing pressure at heel	$q_{heel} = 0 \text{ kN/m}^2$
Effective overburden pressure	$q = (t_{base} + d_{cover}) \times \gamma_{b'} = 5.4 \text{ kN/m}^2$
Design effective overburden pressure	$q' = q / \gamma_{\gamma} = 5.4 \text{ kN/m}^2$
Bearing resistance factors	$N_q = \text{Exp}(\pi \times \tan(\phi'_{b,d})) \times (\tan(45 \text{ deg} + \phi'_{b,d} / 2))^2 = 33.296$ $N_c = (N_q - 1) \times \cot(\phi'_{b,d}) = 46.124$ $N_{\gamma} = 2 \times (N_q - 1) \times \tan(\phi'_{b,d}) = 45.228$
Foundation shape factors	$s_q = 1$ $s_{\gamma} = 1$ $s_c = 1$
Load inclination factors	$H = F_{sur_h} + F_{moist_h} + F_{pass_h} = 19.9 \text{ kN/m}$ $V = F_{total_v} = 90.4 \text{ kN/m}$ $m = 2$ $i_q = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^m = 0.608$ $i_{\gamma} = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^{(m+1)} = 0.474$ $i_c = i_q - (1 - i_q) / (N_c \times \tan(\phi'_{b,d})) = 0.595$
Net ultimate bearing capacity	$n_f = c'_{b,d} \times N_c \times s_c \times i_c + q' \times N_q \times s_q \times i_q + 0.5 \times \gamma_{b'} \times l_{load} \times N_{\gamma} \times s_{\gamma} \times i_{\gamma} = 342.5 \text{ kN/m}^2$
Factor of safety	$FoS_{bp} = n_f / \max(q_{toe}, q_{heel}) = 4.587$ PASS - Allowable bearing pressure exceeds maximum applied bearing pressure

Design approach 1

Partial factors on actions - Table A.3 - Combination 2

Partial factor set	A2
Permanent unfavourable action	$\gamma_G = 1.000$
Permanent favourable action	$\gamma_{Gf} = 1.000$
Variable unfavourable action	$\gamma_Q = 1.300$
Variable favourable action	$\gamma_{Qf} = 0.000$

Partial factors for soil parameters – Table A.4 - Combination 2

Soil parameter set	M2
Angle of shearing resistance	$\gamma_{\phi'} = 1.25$
Effective cohesion	$\gamma_{c'} = 1.25$
Weight density	$\gamma_{\gamma} = 1.00$

Retained soil properties

Design moist density	$\gamma_{mr}' = \gamma_{mr} / \gamma_{\gamma} = 21 \text{ kN/m}^3$
Design saturated density	$\gamma_{sr}' = \gamma_{sr} / \gamma_{\gamma} = 23 \text{ kN/m}^3$
Design effective shear resistance angle	$\phi'_{r,d} = \text{atan}(\tan(\phi'_{r,k}) / \gamma_{\phi'}) = 29.3 \text{ deg}$
Design wall friction angle	$\delta_{r,d} = \text{atan}(\tan(\delta_{r,k}) / \gamma_{\phi'}) = 14.2 \text{ deg}$

Base soil properties

Design soil density	$\gamma_{b'} = \gamma_b / \gamma_{\gamma} = 18 \text{ kN/m}^3$
Design effective shear resistance angle	$\phi'_{b,d} = \text{atan}(\tan(\phi'_{b,k}) / \gamma_{\phi'}) = 29.3 \text{ deg}$
Design wall friction angle	$\delta_{b,d} = \text{atan}(\tan(\delta_{b,k}) / \gamma_{\phi'}) = 12.1 \text{ deg}$
Design base friction angle	$\delta_{bb,d} = \text{atan}(\tan(\delta_{bb,k}) / \gamma_{\phi'}) = 24.8 \text{ deg}$

Project				Job no.	
Calcs for				Start page no./Revision 6	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Design effective cohesion

$$c'_{b,d} = c'_{b,k} / \gamma_c = 0 \text{ kN/m}^2$$

Using Coulomb theory

Active pressure coefficient

$$K_A = \sin(\alpha + \phi'_{r,d})^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta_{r,d}) \times [1 + \sqrt{[\sin(\phi'_{r,d} + \delta_{r,d}) \times \sin(\phi'_{r,d} - \beta) / (\sin(\alpha - \delta_{r,d}) \times \sin(\alpha + \beta))]}])^2 = 0.411$$

Passive pressure coefficient

$$K_P = \sin(90 - \phi'_{b,d})^2 / (\sin(90 + \delta_{b,d}) \times [1 - \sqrt{[\sin(\phi'_{b,d} + \delta_{b,d}) \times \sin(\phi'_{b,d}) / (\sin(90 + \delta_{b,d}))]}])^2 = 4.303$$

Sliding check

Vertical forces on wall

Wall stem

$$F_{\text{stem}} = \gamma G_f \times A_{\text{stem}} \times \gamma_{\text{stem}} = 9.3 \text{ kN/m}$$

Wall base

$$F_{\text{base}} = \gamma G_f \times A_{\text{base}} \times \gamma_{\text{base}} = 11.3 \text{ kN/m}$$

Moist retained soil

$$F_{\text{moist}_v} = \gamma G_f \times A_{\text{moist}} \times \gamma_{\text{mr}} = 43.3 \text{ kN/m}$$

Total

$$F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} = 63.8 \text{ kN/m}$$

Horizontal forces on wall

Surcharge load

$$F_{\text{sur}_h} = K_A \times \cos(\delta_{r,d}) \times \gamma Q \times \text{Surcharge}_Q \times h_{\text{eff}} = 3 \text{ kN/m}$$

Moist retained soil

$$F_{\text{moist}_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{\text{mr}} \times h_{\text{eff}}^2 / 2 = 22.5 \text{ kN/m}$$

Total

$$F_{\text{total}_h} = F_{\text{sur}_h} + F_{\text{moist}_h} = 25.5 \text{ kN/m}$$

Check stability against sliding

Base soil resistance

$$F_{\text{exc}_h} = \gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b \times (h_{\text{pass}} + h_{\text{base}})^2 / 2 = 3.4 \text{ kN/m}$$

Base friction

$$F_{\text{friction}} = F_{\text{total}_v} \times \tan(\delta_{bb,d}) = 29.5 \text{ kN/m}$$

Resistance to sliding

$$F_{\text{rest}} = F_{\text{exc}_h} + F_{\text{friction}} = 32.9 \text{ kN/m}$$

Factor of safety

$$F_{\text{OSsl}} = F_{\text{rest}} / F_{\text{total}_h} = 1.292$$

PASS - Resistance to sliding is greater than sliding force

Overtuning check

Vertical forces on wall

Wall stem

$$F_{\text{stem}} = \gamma G_f \times A_{\text{stem}} \times \gamma_{\text{stem}} = 9.3 \text{ kN/m}$$

Wall base

$$F_{\text{base}} = \gamma G_f \times A_{\text{base}} \times \gamma_{\text{base}} = 11.3 \text{ kN/m}$$

Moist retained soil

$$F_{\text{moist}_v} = \gamma G_f \times A_{\text{moist}} \times \gamma_{\text{mr}} = 43.3 \text{ kN/m}$$

Total

$$F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} = 63.8 \text{ kN/m}$$

Horizontal forces on wall

Surcharge load

$$F_{\text{sur}_h} = K_A \times \cos(\delta_{r,d}) \times \gamma Q \times \text{Surcharge}_Q \times h_{\text{eff}} = 3 \text{ kN/m}$$

Moist retained soil

$$F_{\text{moist}_h} = \gamma G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{\text{mr}} \times h_{\text{eff}}^2 / 2 = 22.5 \text{ kN/m}$$

Base soil

$$F_{\text{exc}_h} = -\gamma G_f \times K_P \times \cos(\delta_{b,d}) \times \gamma_b \times (h_{\text{pass}} + h_{\text{base}})^2 / 2 = -3.4 \text{ kN/m}$$

Total

$$F_{\text{total}_h} = F_{\text{sur}_h} + F_{\text{moist}_h} + F_{\text{exc}_h} = 22 \text{ kN/m}$$

Overtuning moments on wall

Surcharge load

$$M_{\text{sur}_OT} = F_{\text{sur}_h} \times X_{\text{sur}_h} = 3.5 \text{ kNm/m}$$

Moist retained soil

$$M_{\text{moist}_OT} = F_{\text{moist}_h} \times X_{\text{moist}_h} = 17.3 \text{ kNm/m}$$

Total

$$M_{\text{total}_OT} = M_{\text{sur}_OT} + M_{\text{moist}_OT} = 20.8 \text{ kNm/m}$$

Restoring moments on wall

Wall stem

$$M_{\text{stem}_R} = F_{\text{stem}} \times X_{\text{stem}} = 2.4 \text{ kNm/m}$$

Wall base

$$M_{\text{base}_R} = F_{\text{base}} \times X_{\text{base}} = 8.4 \text{ kNm/m}$$

Moist retained soil

$$M_{\text{moist}_R} = F_{\text{moist}_v} \times X_{\text{moist}_v} = 41.4 \text{ kNm/m}$$

Base soil

$$M_{\text{exc}_R} = -F_{\text{exc}_h} \times X_{\text{exc}_h} = 0.3 \text{ kNm/m}$$

Total

$$M_{\text{total}_R} = M_{\text{stem}_R} + M_{\text{base}_R} + M_{\text{moist}_R} + M_{\text{exc}_R} = 52.6 \text{ kNm/m}$$

Project				Job no.	
Calcs for				Start page no./Revision 7	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Check stability against overturning

Factor of safety

$$FoS_{ot} = M_{total_R} / M_{total_OT} = \mathbf{2.529}$$

PASS - Maximum restoring moment is greater than overturning moment

Bearing pressure check

Vertical forces on wall

Wall stem

$$F_{stem} = \gamma_G \times A_{stem} \times \gamma_{stem} = \mathbf{9.3 \text{ kN/m}}$$

Wall base

$$F_{base} = \gamma_G \times A_{base} \times \gamma_{base} = \mathbf{11.3 \text{ kN/m}}$$

Surcharge load

$$F_{sur_v} = \gamma_Q \times \text{Surcharge}_Q \times l_{heel} = \mathbf{3.7 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_v} = \gamma_G \times A_{moist} \times \gamma_{mr}' = \mathbf{43.3 \text{ kN/m}}$$

Total

$$F_{total_v} = F_{stem} + F_{base} + F_{sur_v} + F_{moist_v} = \mathbf{67.5 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge load

$$F_{sur_h} = K_A \times \cos(\delta_{r,d}) \times \gamma_Q \times \text{Surcharge}_Q \times h_{eff} = \mathbf{3 \text{ kN/m}}$$

Moist retained soil

$$F_{moist_h} = \gamma_G \times K_A \times \cos(\delta_{r,d}) \times \gamma_{mr}' \times h_{eff}^2 / 2 = \mathbf{22.5 \text{ kN/m}}$$

Base soil

$$F_{pass_h} = -\gamma_G \times K_P \times \cos(\delta_{b,d}) \times \gamma_{b'} \times (d_{cover} + h_{base})^2 / 2 = \mathbf{-3.4 \text{ kN/m}}$$

Total

$$F_{total_h} = \max(F_{sur_h} + F_{moist_h} + F_{pass_h} - F_{total_v} \times \tan(\delta_{bb,d}), 0 \text{ kN/m}) = \mathbf{0 \text{ kN/m}}$$

Moments on wall

Wall stem

$$M_{stem} = F_{stem} \times X_{stem} = \mathbf{2.4 \text{ kNm/m}}$$

Wall base

$$M_{base} = F_{base} \times X_{base} = \mathbf{8.4 \text{ kNm/m}}$$

Surcharge load

$$M_{sur} = F_{sur_v} \times X_{sur_v} - F_{sur_h} \times X_{sur_h} = \mathbf{0 \text{ kNm/m}}$$

Moist retained soil

$$M_{moist} = F_{moist_v} \times X_{moist_v} - F_{moist_h} \times X_{moist_h} = \mathbf{24.1 \text{ kNm/m}}$$

Base soil

$$M_{pass} = -F_{pass_h} \times X_{pass_h} = \mathbf{0.3 \text{ kNm/m}}$$

Total

$$M_{total} = M_{stem} + M_{base} + M_{sur} + M_{moist} + M_{pass} = \mathbf{35.2 \text{ kNm/m}}$$

Check bearing pressure

Distance to reaction

$$\bar{x} = M_{total} / F_{total_v} = \mathbf{522 \text{ mm}}$$

Eccentricity of reaction

$$e = \bar{x} - l_{base} / 2 = \mathbf{-228 \text{ mm}}$$

Loaded length of base

$$l_{load} = 2 \times \bar{x} = \mathbf{1044 \text{ mm}}$$

Bearing pressure at toe

$$q_{toe} = F_{total_v} / l_{load} = \mathbf{64.6 \text{ kN/m}^2}$$

Bearing pressure at heel

$$q_{heel} = \mathbf{0 \text{ kN/m}^2}$$

Effective overburden pressure

$$q = (t_{base} + d_{cover}) \times \gamma_{b'} = \mathbf{5.4 \text{ kN/m}^2}$$

Design effective overburden pressure

$$q' = q / \gamma_{\gamma} = \mathbf{5.4 \text{ kN/m}^2}$$

Bearing resistance factors

$$N_q = \text{Exp}(\pi \times \tan(\phi'_{b,d})) \times (\tan(45 \text{ deg} + \phi'_{b,d} / 2))^2 = \mathbf{16.921}$$

$$N_c = (N_q - 1) \times \cot(\phi'_{b,d}) = \mathbf{28.422}$$

$$N_{\gamma} = 2 \times (N_q - 1) \times \tan(\phi'_{b,d}) = \mathbf{17.837}$$

Foundation shape factors

$$s_q = 1$$

$$s_{\gamma} = 1$$

$$s_c = 1$$

Load inclination factors

$$H = F_{sur_h} + F_{moist_h} + F_{pass_h} = \mathbf{22 \text{ kN/m}}$$

$$V = F_{total_v} = \mathbf{67.5 \text{ kN/m}}$$

$$m = 2$$

$$i_q = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^m = \mathbf{0.453}$$

$$i_{\gamma} = [1 - H / (V + l_{load} \times c'_{b,d} \times \cot(\phi'_{b,d}))]^{(m+1)} = \mathbf{0.305}$$

$$i_c = i_q - (1 - i_q) / (N_c \times \tan(\phi'_{b,d})) = \mathbf{0.419}$$

Net ultimate bearing capacity

Project				Job no.	
Calcs for				Start page no./Revision 8	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

$$n_f = c'_{b,d} \times N_c \times s_c \times i_c + q' \times N_q \times s_q \times i_q + 0.5 \times \gamma_b' \times l_{load} \times N_\gamma \times s_\gamma \times i_\gamma = 92.6 \text{ kN/m}^2$$

Factor of safety

$$FoS_{bp} = n_f / \max(q_{toe}, q_{heel}) = 1.433$$

PASS - Allowable bearing pressure exceeds maximum applied bearing pressure

RETAINING WALL DESIGN

In accordance with EN1992-1-1:2004 incorporating Corrigendum dated January 2008 and the UK National Annex incorporating National Amendment No.1

Tedds calculation version 2.9.22

Concrete details - Table 3.1 - Strength and deformation characteristics for concrete

Concrete strength class	C30/37
Characteristic compressive cylinder strength	$f_{ck} = 30 \text{ N/mm}^2$
Characteristic compressive cube strength	$f_{ck,cube} = 37 \text{ N/mm}^2$
Mean value of compressive cylinder strength	$f_{cm} = f_{ck} + 8 \text{ N/mm}^2 = 38 \text{ N/mm}^2$
Mean value of axial tensile strength	$f_{ctm} = 0.3 \text{ N/mm}^2 \times (f_{ck} / 1 \text{ N/mm}^2)^{2/3} = 2.9 \text{ N/mm}^2$
5% fractile of axial tensile strength	$f_{ctk,0.05} = 0.7 \times f_{ctm} = 2.0 \text{ N/mm}^2$
Secant modulus of elasticity of concrete	$E_{cm} = 22 \text{ kN/mm}^2 \times (f_{cm} / 10 \text{ N/mm}^2)^{0.3} = 32837 \text{ N/mm}^2$
Partial factor for concrete - Table 2.1N	$\gamma_C = 1.50$
Compressive strength coefficient - cl.3.1.6(1)	$\alpha_{cc} = 0.85$
Design compressive concrete strength - exp.3.15	$f_{cd} = \alpha_{cc} \times f_{ck} / \gamma_C = 17.0 \text{ N/mm}^2$
Maximum aggregate size	$h_{agg} = 20 \text{ mm}$
Ultimate strain - Table 3.1	$\epsilon_{cu2} = 0.0035$
Shortening strain - Table 3.1	$\epsilon_{cu3} = 0.0035$
Effective compression zone height factor	$\lambda = 0.80$
Effective strength factor	$\eta = 1.00$
Bending coefficient k_1	$K_1 = 0.40$
Bending coefficient k_2	$K_2 = 1.00 \times (0.6 + 0.0014/\epsilon_{cu2}) = 1.00$
Bending coefficient k_3	$K_3 = 0.40$
Bending coefficient k_4	$K_4 = 1.00 \times (0.6 + 0.0014/\epsilon_{cu2}) = 1.00$







Reinforcement details

Characteristic yield strength of reinforcement	$f_{yk} = 500 \text{ N/mm}^2$
Modulus of elasticity of reinforcement	$E_s = 200000 \text{ N/mm}^2$
Partial factor for reinforcing steel - Table 2.1N	$\gamma_S = 1.15$
Design yield strength of reinforcement	$f_{yd} = f_{yk} / \gamma_S = 435 \text{ N/mm}^2$

Cover to reinforcement

Front face of stem	$c_{sf} = 40 \text{ mm}$
Rear face of stem	$c_{sr} = 50 \text{ mm}$
Top face of base	$c_{bt} = 50 \text{ mm}$
Bottom face of base	$c_{bb} = 75 \text{ mm}$

Project				Job no.	
Calcs for				Start page no./Revision 9	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date



Check stem design at base of stem

Depth of section

$h = 225 \text{ mm}$

Rectangular section in flexure - Section 6.1

Design bending moment combination 2

$M = 8 \text{ kNm/m}$

Depth to tension reinforcement

$d = h - C_{sr} - \phi_{sr} / 2 = 170 \text{ mm}$

$K = M / (d^2 \times f_{ck}) = 0.009$

$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$

$K' = 0.207$

$K' > K$ - No compression reinforcement is required

Lever arm

$z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 161 \text{ mm}$

Depth of neutral axis

$x = 2.5 \times (d - z) = 21 \text{ mm}$

Area of tension reinforcement required

$A_{sr,req} = M / (f_{yd} \times z) = 114 \text{ mm}^2/\text{m}$

Tension reinforcement provided

10 dia.bars @ 200 c/c



Project				Job no.	
Calcs for				Start page no./Revision 10	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Area of tension reinforcement provided

$$A_{sr,prov} = \pi \times \phi_{sr}^2 / (4 \times s_{sr}) = \mathbf{393 \text{ mm}^2/m}$$

Minimum area of reinforcement - exp.9.1N

$$A_{sr,min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = \mathbf{256 \text{ mm}^2/m}$$

Maximum area of reinforcement - cl.9.2.1.1(3)

$$A_{sr,max} = 0.04 \times h = \mathbf{9000 \text{ mm}^2/m}$$

$$\max(A_{sr,req}, A_{sr,min}) / A_{sr,prov} = \mathbf{0.652}$$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Deflection control - Section 7.4

Reference reinforcement ratio

$$\rho_0 = \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} / 1000 = \mathbf{0.005}$$

Required tension reinforcement ratio

$$\rho = A_{sr,req} / d = \mathbf{0.001}$$

Required compression reinforcement ratio

$$\rho' = A_{sr,2,req} / d_2 = \mathbf{0.000}$$

Structural system factor - Table 7.4N

$$K_b = \mathbf{0.4}$$

Reinforcement factor - exp.7.17

$$K_s = \min(500 \text{ N/mm}^2 / (f_{yk} \times A_{sr,req} / A_{sr,prov}), 1.5) = \mathbf{1.5}$$

Limiting span to depth ratio - exp.7.16.a

$$\min(K_s \times K_b \times [11 + 1.5 \times \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} \times \rho_0 / \rho + 3.2 \times \sqrt{(f_{ck} / 1 \text{ N/mm}^2)} \times (\rho_0 / \rho - 1)^{3/2}], 40 \times K_b) = \mathbf{16}$$

Actual span to depth ratio

$$h_{stem} / d = \mathbf{9.7}$$

PASS - Span to depth ratio is less than deflection control limit

Crack control - Section 7.3

Limiting crack width

$$w_{max} = \mathbf{0.3 \text{ mm}}$$

Variable load factor - EN1990 – Table A1.1

$$\psi_2 = \mathbf{0.6}$$

Serviceability bending moment

$$M_{sls} = \mathbf{5.3 \text{ kNm/m}}$$

Tensile stress in reinforcement

$$\sigma_s = M_{sls} / (A_{sr,prov} \times z) = \mathbf{82.9 \text{ N/mm}^2}$$

Load duration

Long term

Load duration factor

$$k_t = \mathbf{0.4}$$

Effective area of concrete in tension

$$A_{c,eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$$

$$A_{c,eff} = \mathbf{67917 \text{ mm}^2/m}$$

Mean value of concrete tensile strength

$$f_{ct,eff} = f_{ctm} = \mathbf{2.9 \text{ N/mm}^2}$$

Reinforcement ratio

$$\rho_{p,eff} = A_{sr,prov} / A_{c,eff} = \mathbf{0.006}$$

Modular ratio

$$\alpha_e = E_s / E_{cm} = \mathbf{6.091}$$

Bond property coefficient

$$k_1 = \mathbf{0.8}$$

Strain distribution coefficient

$$k_2 = \mathbf{0.5}$$

$$k_3 = \mathbf{3.4}$$

$$k_4 = \mathbf{0.425}$$

Maximum crack spacing - exp.7.11

$$s_{r,max} = k_3 \times C_{sr} + k_1 \times k_2 \times k_4 \times \phi_{sr} / \rho_{p,eff} = \mathbf{464 \text{ mm}}$$

Maximum crack width - exp.7.8

$$w_k = s_{r,max} \times \max(\sigma_s - k_t \times (f_{ct,eff} / \rho_{p,eff}) \times (1 + \alpha_e \times \rho_{p,eff}), 0.6 \times \sigma_s) / E_s$$

$$w_k = \mathbf{0.115 \text{ mm}}$$

$$w_k / w_{max} = \mathbf{0.385}$$

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$$V = \mathbf{13.5 \text{ kN/m}}$$

$$C_{Rd,c} = 0.18 / \gamma_c = \mathbf{0.120}$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = \mathbf{2.000}$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{sr,prov} / d, 0.02) = \mathbf{0.002}$$

$$v_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = \mathbf{0.542 \text{ N/mm}^2}$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, v_{min}) \times d$$

$$V_{Rd,c} = \mathbf{92.2 \text{ kN/m}}$$

$$V / V_{Rd,c} = \mathbf{0.147}$$



Project				Job no.	
Calcs for				Start page no./Revision 11	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

PASS - Design shear resistance exceeds design shear force

Horizontal reinforcement parallel to face of stem - Section 9.6

Minimum area of reinforcement – cl.9.6.3(1) $A_{sx,req} = \max(0.25 \times A_{sr,prov}, 0.001 \times t_{stem}) = 225 \text{ mm}^2/\text{m}$

Maximum spacing of reinforcement – cl.9.6.3(2) $s_{sx,max} = 400 \text{ mm}$

Transverse reinforcement provided 10 dia.bars @ 200 c/c

Area of transverse reinforcement provided $A_{sx,prov} = \pi \times \phi_{sx}^2 / (4 \times s_{sx}) = 393 \text{ mm}^2/\text{m}$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Check base design at toe

Depth of section $h = 300 \text{ mm}$

Rectangular section in flexure - Section 6.1

Design bending moment combination 1 $M = 1.4 \text{ kNm/m}$

Depth to tension reinforcement $d = h - C_{bb} - \phi_{bb} / 2 = 219 \text{ mm}$

$K = M / (d^2 \times f_{ck}) = 0.001$

$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$

$K' = 0.207$

$K' > K$ - No compression reinforcement is required

Lever arm $z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 208 \text{ mm}$

Depth of neutral axis $x = 2.5 \times (d - z) = 27 \text{ mm}$

Area of tension reinforcement required $A_{bb,req} = M / (f_{yd} \times z) = 15 \text{ mm}^2/\text{m}$

Tension reinforcement provided 12 dia.bars @ 200 c/c

Area of tension reinforcement provided $A_{bb,prov} = \pi \times \phi_{bb}^2 / (4 \times s_{bb}) = 565 \text{ mm}^2/\text{m}$

Minimum area of reinforcement - exp.9.1N $A_{bb,min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = 330 \text{ mm}^2/\text{m}$

Maximum area of reinforcement - cl.9.2.1.1(3) $A_{bb,max} = 0.04 \times h = 12000 \text{ mm}^2/\text{m}$

$\max(A_{bb,req}, A_{bb,min}) / A_{bb,prov} = 0.583$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Crack control - Section 7.3

Limiting crack width $w_{max} = 0.3 \text{ mm}$

Variable load factor - EN1990 – Table A1.1 $\psi_2 = 0.6$

Serviceability bending moment $M_{sls} = 1 \text{ kNm/m}$

Tensile stress in reinforcement $\sigma_s = M_{sls} / (A_{bb,prov} \times z) = 8.4 \text{ N/mm}^2$

Load duration Long term

Load duration factor $k_t = 0.4$

Effective area of concrete in tension $A_{c,eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$

$A_{c,eff} = 90875 \text{ mm}^2/\text{m}$

Mean value of concrete tensile strength $f_{ct,eff} = f_{ctm} = 2.9 \text{ N/mm}^2$

Reinforcement ratio $\rho_{p,eff} = A_{bb,prov} / A_{c,eff} = 0.006$

Modular ratio $\alpha_e = E_s / E_{cm} = 6.091$

Bond property coefficient $k_1 = 0.8$

Strain distribution coefficient $k_2 = 0.5$

$k_3 = 3.4$

$k_4 = 0.425$

Maximum crack spacing - exp.7.11 $s_{r,max} = k_3 \times C_{bb} + k_1 \times k_2 \times k_4 \times \phi_{bb} / \rho_{p,eff} = 583 \text{ mm}$

Maximum crack width - exp.7.8 $w_k = s_{r,max} \times \max(\sigma_s - k_t \times (f_{ct,eff} / \rho_{p,eff}) \times (1 + \alpha_e \times \rho_{p,eff}), 0.6 \times \sigma_s) / E_s$

$w_k = 0.015 \text{ mm}$

$w_k / w_{max} = 0.049$



Project				Job no.	
Calcs for				Start page no./Revision 12	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$V = 11.6 \text{ kN/m}$

$C_{Rd,c} = 0.18 / \gamma_c = 0.120$

$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = 1.956$

Longitudinal reinforcement ratio

$\rho_l = \min(A_{bb,prov} / d, 0.02) = 0.003$

$V_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = 0.524 \text{ N/mm}^2$

Design shear resistance - exp.6.2a & 6.2b

$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, V_{min}) \times d$

$V_{Rd,c} = 114.8 \text{ kN/m}$

$V / V_{Rd,c} = 0.101$

PASS - Design shear resistance exceeds design shear force

Check base design at heel

Depth of section

$h = 300 \text{ mm}$

Rectangular section in flexure - Section 6.1

Design bending moment combination 2

$M = 7 \text{ kNm/m}$

Depth to tension reinforcement

$d = h - c_{bt} - \phi_{bt} / 2 = 244 \text{ mm}$

$K = M / (d^2 \times f_{ck}) = 0.004$

$K' = (2 \times \eta \times \alpha_{cc} / \gamma_c) \times (1 - \lambda \times (\delta - K_1) / (2 \times K_2)) \times (\lambda \times (\delta - K_1) / (2 \times K_2))$

$K' = 0.207$

$K' > K$ - No compression reinforcement is required

Lever arm

$z = \min(0.5 + 0.5 \times (1 - 2 \times K / (\eta \times \alpha_{cc} / \gamma_c))^{0.5}, 0.95) \times d = 232 \text{ mm}$

Depth of neutral axis

$x = 2.5 \times (d - z) = 31 \text{ mm}$

Area of tension reinforcement required

$A_{bt,req} = M / (f_{yd} \times z) = 70 \text{ mm}^2/\text{m}$

Tension reinforcement provided

12 dia.bars @ 200 c/c

Area of tension reinforcement provided

$A_{bt,prov} = \pi \times \phi_{bt}^2 / (4 \times s_{bt}) = 565 \text{ mm}^2/\text{m}$

Minimum area of reinforcement - exp.9.1N

$A_{bt,min} = \max(0.26 \times f_{ctm} / f_{yk}, 0.0013) \times d = 368 \text{ mm}^2/\text{m}$

Maximum area of reinforcement - cl.9.2.1.1(3)

$A_{bt,max} = 0.04 \times h = 12000 \text{ mm}^2/\text{m}$

$\max(A_{bt,req}, A_{bt,min}) / A_{bt,prov} = 0.65$

PASS - Area of reinforcement provided is greater than area of reinforcement required

Library item: Rectangular single output

Crack control - Section 7.3

Limiting crack width

$w_{max} = 0.3 \text{ mm}$

Variable load factor - EN1990 – Table A1.1

$\psi_2 = 0.6$

Serviceability bending moment

$M_{sis} = 4.2 \text{ kNm/m}$

Tensile stress in reinforcement

$\sigma_s = M_{sis} / (A_{bt,prov} \times z) = 31.7 \text{ N/mm}^2$

Load duration

Long term

Load duration factor

$k_t = 0.4$

Effective area of concrete in tension

$A_{c,eff} = \min(2.5 \times (h - d), (h - x) / 3, h / 2)$

$A_{c,eff} = 89833 \text{ mm}^2/\text{m}$

Mean value of concrete tensile strength

$f_{ct,eff} = f_{ctm} = 2.9 \text{ N/mm}^2$

Reinforcement ratio

$\rho_{p,eff} = A_{bt,prov} / A_{c,eff} = 0.006$

Modular ratio

$\alpha_e = E_s / E_{cm} = 6.091$

Bond property coefficient

$k_1 = 0.8$

Strain distribution coefficient

$k_2 = 0.5$

$k_3 = 3.4$

$k_4 = 0.425$

Project				Job no.	
Calcs for				Start page no./Revision 13	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

Maximum crack spacing - exp.7.11

$$s_{r,max} = k_3 \times C_{bt} + k_1 \times k_2 \times k_4 \times \phi_{bt} / \rho_{p,eff} = \mathbf{494 \text{ mm}}$$

Maximum crack width - exp.7.8

$$w_k = s_{r,max} \times \max(\sigma_s - k_t \times (f_{ct,eff} / \rho_{p,eff}) \times (1 + \alpha_e \times \rho_{p,eff}), 0.6 \times \sigma_s) / E_s$$

$$w_k = \mathbf{0.047 \text{ mm}}$$

$$w_k / w_{max} = \mathbf{0.157}$$

PASS - Maximum crack width is less than limiting crack width

Rectangular section in shear - Section 6.2

Design shear force

$$V = \mathbf{7.9 \text{ kN/m}}$$

$$C_{Rd,c} = 0.18 / \gamma_C = \mathbf{0.120}$$

$$k = \min(1 + \sqrt{(200 \text{ mm} / d)}, 2) = \mathbf{1.905}$$

Longitudinal reinforcement ratio

$$\rho_l = \min(A_{bt,prov} / d, 0.02) = \mathbf{0.002}$$

$$v_{min} = 0.035 \text{ N}^{1/2}/\text{mm} \times k^{3/2} \times f_{ck}^{0.5} = \mathbf{0.504 \text{ N/mm}^2}$$

Design shear resistance - exp.6.2a & 6.2b

$$V_{Rd,c} = \max(C_{Rd,c} \times k \times (100 \text{ N}^2/\text{mm}^4 \times \rho_l \times f_{ck})^{1/3}, v_{min}) \times d$$

$$V_{Rd,c} = \mathbf{123 \text{ kN/m}}$$

$$V / V_{Rd,c} = \mathbf{0.064}$$

PASS - Design shear resistance exceeds design shear force

Secondary transverse reinforcement to base - Section 9.3

Minimum area of reinforcement – cl.9.3.1.1(2)

$$A_{bx,req} = 0.2 \times A_{bb,prov} = \mathbf{113 \text{ mm}^2/\text{m}}$$

Maximum spacing of reinforcement – cl.9.3.1.1(3)

$$s_{bx,max} = \mathbf{450 \text{ mm}}$$


Transverse reinforcement provided

$$\mathbf{10 \text{ dia. bars @ } 200 \text{ c/c}}$$

Area of transverse reinforcement provided

$$A_{bx,prov} = \pi \times \phi_{bx}^2 / (4 \times s_{bx}) = \mathbf{393 \text{ mm}^2/\text{m}}$$

PASS - Area of reinforcement provided is greater than area of reinforcement required





Tekla® Tedds

Shear Design
7 Ash Tree Court
Cardiff Gate Business Park
CF23 8RW

Project				Job no.	
Calcs for				Start page no./Revision 14	
Calcs by J	Calcs date 04/12/2024	Checked by	Checked date	Approved by	Approved date

